

**OPERATIONS PLAN**

**NORLITE LLC  
COHOES, NEW YORK  
NYD080469935**

**PREPARED FOR:**

**NORLITE LLC  
628 SOUTH SARATOGA STREET  
COHOES, NEW YORK 12047**

**PREPARED BY:**

**NORLITE LLC  
628 SOUTH SARATOGA STREET  
COHOES, NEW YORK 12047**

**June 2014**

**OPERATIONS PLAN**  
**TABLE OF CONTENTS**

**1.0 CERTIFICATION AND FACILITY DESCRIPTION**

- 1.1 Certification
- 1.2 General Description
- 1.3 Facility Capacity
- 1.4 Topographic Map
- 1.5 Location Information: Floodplain Standard
- 1.6 Traffic Information

**2.0 PROCEDURES TO PREVENT HAZARDS**

- 2.1 Applicability
- 2.2 Equipment Requirements
  - 2.2.1 Internal Communications
  - 2.2.2 External Communications
  - 2.2.3 Emergency Equipment
  - 2.2.4 Water for Fire Control
  - 2.2.5 Testing and Maintenance of Equipment
- 2.3 Aisle Space Requirement
- 2.4 Integrated Contingency Plan
- 2.5 Preventive Procedures, Structures and Equipment
  - 2.5.1 Unloading Operations
  - 2.5.2 Runoff
  - 2.5.3 Water Supplies
  - 2.5.4 Equipment and Power Failure
  - 2.5.5 Personal Protective Equipment
- 2.6 Prevention of Reaction of Ignitable, Reactive and Incompatible Wastes
  - 2.6.1 Precautions to Prevent Ignition or Reaction of Ignitable or Reactive Wastes
  - 2.6.2 General Precautions for Handling Ignitable or Reactive Wastes and Mixing of Incompatible Wastes
  - 2.6.3 Management of Ignitable or Reactive Wastes in Containers
  - 2.6.4 Management of Incompatible Wastes in Containers
  - 2.6.5 Management of Ignitable or Reactive Wastes in Tanks
  - 2.6.6 Incompatible Wastes in Tanks

**3.0 MANAGEMENT OF WASTES IN CONTAINERS**

- 3.1 Container Management
- 3.2 Containers with Free Liquids

- 3.2.1 Basic Design Parameters, Dimensions and Materials of Construction
- 3.2.2 Description of How Design Promotes Drainage
- 3.2.3 Capacity of the Containment System
- 3.2.4 Provisions for Preventing or Managing Run-on
- 3.2.5 Accumulated Liquids
- 3.3 Containers without Free Liquids
- 3.4 Requirements for Ignitable or Reactive Wastes and Incompatible Wastes

#### **4.0 MANAGEMENT OF WASTES IN TANKS**

- 4.1 Existing Tank Systems
  - 4.1.1 Assessment of Existing Tank Systems
- 4.2 New Tank Systems
  - 4.2.1 Design of New Tank Systems
  - 4.2.2 Installation of New Tank Systems
- 4.3 Secondary Containment for Tank Systems
- 4.4 Double-Walled Tanks/Diked Tanks
- 4.5 General Tank Operating Requirements
- 4.6 Requirements for Ignitable or Reactive Waste Storage in Tanks
- 4.7 Requirements for Incompatible Waste Storage in Tanks
- 4.8 Tank Inspection
  - 4.8.1 Tanks without Secondary Containment
- 4.9 Tank Spills and Leakage
- 4.10 Closure and Post-Closure Care

#### **5.0 RESERVED**

#### **6.0 RESERVED**

#### **7.0 MANAGEMENT OF WASTES IN BOILERS AND INDUSTRIAL FURNACES**

- 7.1 Design and Operation
- 7.2 Waste Analysis
- 7.3 Performance Standards and Operating Requirements
- 7.4 Monitoring and Inspection
- 7.5 Closure

#### **8.0 RESERVED**

#### **9.0 RESERVED**

#### **10.0 AIR EMISSION STANDARDS**

##### **10.1 RESERVED**

- 10.2 Air Emission Standards for Equipment Leaks - Subpart BB
  - 10.2.1 Standards for Equipment
  - 10.2.2 Test Methods and Procedures
  - 10.2.3 Recordkeeping and Reporting Requirements
- 10.3 Air Emission Standards for Tanks, Surface Impoundments and Containers - Subpart CC
  - 10.3.1 Waste Determination Procedures
  - 10.3.2 Standards for Tanks, Surface Impoundments and Containers
  - 10.3.3 Inspection and Monitoring Requirements
  - 10.3.4 Recordkeeping and Reporting Requirements

## **11.0 REQUIREMENTS OF OTHER FEDERAL AND STATE LAWS**

- 11.1 Manifest Requirements
- 11.2 Operating Record
- 11.3 Availability, Retention and Disposition of Records
- 11.4 Annual Report
- 11.5 Hazardous Waste Reduction Plans

## **12.0 GLOSSARY**

### **13. Appendices**

- 1 SOP#4-011**
- 2 SOP#6-001**
- 3 Protectoline 900**
- 4 Sikaflex - 1a**
- 5 Horizontal Tank Plan**
- 6 Compatibility Chart**
- 7 HDPE Liner Details**
- 8 Shell Thickness Measurements**
- 9 Carbomastic 15**
- 10 Cathodic Protection**
- 11 Level Sensors**
- 12 Rupture Disc Certifications**
- 13 Piping Specifications**
- 14 Gasket Materials**
- 15 Chemical-Alloy Compatibility Chart**
- 16 Subpart BB Compliance**
- 17 Subpart CC Compliance**

## **1.0 CERTIFICATION AND FACILITY DESCRIPTION**

Due to the operations and hazardous waste management activities performed at the Norlite LLC (Norlite) located in Cohoes, New York, Norlite LLC is required to obtain a Part 373 Permit from the New York State Department of Environmental Conservation (NYSDEC). As part of the Part 373 Permit application process, the NYSDEC required Norlite LLC to prepare this Operations Plan for the Norlite LLC (Norlite). The purpose of this Operations Plan is to: describe the hazardous waste management activities that occur at the facility and the procedures that have been implemented to properly manage waste in accordance with the 6 NYCRR 373 regulations; describe the design and operation of the hazardous waste management units located at the facility to ensure compliance with the 6 NYCRR 373 regulations; describe compliance with other applicable federal and state regulations; and present the procedures and safeguards implemented at the facility to prevent hazards from adversely impacting human health or the environment.

This Operations Plan is incorporated by reference into the Norlite LLC (Norlite) Part 373 Permit. In the event that changes are made to the facility that affect the content of this Plan, this Plan will be updated in accordance with the requirements of Condition D of Module 1 of the facility's Part 373 Permit.

1.1 Certification

I certify under penalty of law that this document and the Part 373 Permit Application, including all attachments and documents incorporated by reference, were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

**Date:** \_\_\_\_\_

\_\_\_\_\_  
Signature

**Name:** \_\_\_\_\_

**Title:** \_\_\_\_\_

**Company:** \_\_\_\_\_

## 1.2 General Description

Norlite LLC (Norlite) is located on the southern boundary of the City of Cohoes, New York. Norlite LLC is a wholly owned subsidiary of Tradebe Environmental Services LLC. Norlite's aggregate plant has been in existence since 1956. The facility consists of a production operation and a quarry for shale. Norlite's processing facility occupies about 12 acres of a 221 acres plot owned by Norlite.

The Norlite facility produces an expanded shale aggregate in two dry process rotary kilns. Raw materials are quarried on-site and transported to the kilns via a conveyor system. Kiln No. 1, manufactured by Taylor is 175 feet long, whereas Kiln No. 2, manufactured by Allis-Chalmers, is 180 feet long. Both kilns have an outside diameter of 11 feet and consist of a steel shell lined with 6-inch refractory brick, for an effective inside diameter of 10 feet. The operation is used in the production of lightweight building materials and construction products.

Norlite receives industrial organic wastes (hazardous waste), specification and off-specification used oil, fuel oil, and comparable fuels (in addition to natural gas) for use in its two kilns. These materials are tested in accordance with the Waste Analysis Plan (WAP) to ensure the wastes may be accepted at the facility under the facility's RCRA permit for use as liquid low grade fuel (LLGF). Additionally, the analysis is used to determine the composition of the waste to ensure compliance with emissions from the kilns.

Norlite uses a mixture of these energy sources as fuel for its two kilns. The raw shale and fuel source are fed into the hot end of the kiln at a specified feed rate. Temperatures within the kilns are maintained within the permit required range. Emissions from the kilns are then fed through an emissions control systems.

Both kilns have identical emission control systems. The systems include both wet and dry emission control devices for the collection and removal of particulate matter, hydrogen chloride (HCl), metals, and other gaseous species.

1.3 Facility Capacity

Capacity Authorized (Existing)

Current authorized storage area, waste types and capacity for LLGF is as follows:

AREA	ACTIVITY AND WASTE TYPE <sup>1,2</sup>	AUTHORIZED CONTAINER VOLUMES <sup>3,4</sup>	MAXIMUM VOLUME
<b>CONTAINER MANAGEMENT AREAS</b>			
LLGF and Solids Processing Building	Liquid Waste  Storage in 5, 15, 30, 55 and 85 gallon drums.  Emptying drums to Tank 200A.	5, 15, 30, 55 Gallon Drums	9,900 gallons in 180 55-gallon drum equivalents
Truck Unloading Area	Liquid Waste  Storage in 5, 15, 30, 55 and 85 gallon drums	5, 15, 30, 55 Gallon Drums	4,785 gallons in 87 55-gallon drum equivalents
<b>TANKER TRUCK AND ROLL-OFF MANAGEMENT AREA</b>			
Tanker Truck & Onsite Roll-off Staging Area	Onsite generated non-liquid solid waste (baghouse bags, PPE) stored in roll-offs, Offsite generated solid or hazardous waste tankers and	Up to 50 cubic yard rolloff, 8,000 gallon tanker trucks, single trailer drum transport trucks	13 parking spaces (60' x 200')

	transports, containers for transportation-related temporary storage and/or transfer	Roll-off for storage	
<b>TANK MANAGEMENT AREA</b>			
LLGF Building	LLGF Storage and blending in tanks 100A, 100B, 100C, 200A, 200B, and 200C	8,613 Gal 8,613 Gal 8,613 Gal 9,271 Gal 8,613 Gal 8,613 Gal	9,491 Gal 9,491 Gal 9,491 Gal 10,663 Gal 9,491 Gal 9,491 Gal
Covered Tanks	LLGF Storage and blending in tanks 300, 400, 500, and 600	26,682 Gal 26,682 Gal 26,682 Gal 17,974 Gal	27,903 Gal 27,903 Gal 27,903 Gal 18,940 Gal
Equalization Tanks	LLGF Storage and blending in tanks 101A, 101B, 102A and 102B	1,174 Gal 1,174 Gal 1,174 Gal 1,174 Gal	1,266 Gal 1,266 Gal 1,266 Gal 1,266 Gal
LLGF and Solids Processing Building	LLGF Operating SP100 dispersion tank.	527 Gal	623 Gal

1. Unit codes are as described in the Part A Application.
2. Specific waste types and waste codes are presented in Schedule 1 of Module I: Exhibit C (containers), and Exhibit D (tanks) and in the WAP incorporated by reference into this Permit.
3. 85-gallon overpacks can be used to secure leaking/damaged drums.
4. The total volume stored in drums shall not exceed 14,700 gallons, which is equivalent to 267 55-gallon drums.

#### 1.4 Topographic Map

6NYCRR Subpart §373-1.5(a)(2)(xix) requires that the application contain a topographical map containing a variety of specified parameters. The map includes all of the specified parameters. The topographical map and wind rose included in this application are set forth as follows:

Drawing NY003-373-1 is a topographic map with a scale of 1 inch equals 200 feet and contour intervals of 5 feet. Drawing NY003-373-1 shows the facility legal property line boundaries, an area extending 1000 feet beyond the facility property line and surrounding land uses. It also contains the annual wind rose. The annual wind rose is based on data generated by the National Weather Service Station at the Albany, New York Airport. This weather station is located approximately 5.3 air miles west of the site and is the closest station to the site. This drawing also shows the 100-year floodplain area, surface waters including intermittent streams and direction of their flow.

The special additional information requirements for the protection of the groundwater of 6NYCRR Subpart §373-1.5(a)(3) are not applicable because Norlite does not operate hazardous waste surface impoundments, land treatment units or landfills.

#### 1.5 Location Information: Floodplain Standard

The topographical map in Drawing NY003-373-1 shows the 100-year floodplain area at the facility and hazardous waste operations units at the facility. The 100-year floodplain information was obtained from the Flood Hazard Boundary Maps for the City of Cohoes prepared as part of the National Flood Insurance Program.

The hazardous waste operating units at the facility are not located within the 100-year floodplain and therefore are not affected by the 100-year floodplain requirements of 6NYCRR subpart §373-2.2(j)(1). Accordingly, the information requirements of 6NYCRR subpart §373-1.5(2)(xi)(b) are not applicable.

## 1.6 Traffic Information

6NYCRR Subpart §373-1.5(a)(2)(x) requires information on the traffic patterns in and around the vicinity of the facility. The intent of requiring submittal of the traffic related information is to insure that the movement of hazardous waste will be conducted safely to minimize the risk of accident. The traffic patterns at Norlite's facility support such a determination.

The hazardous waste movement at the plant for on-site processing and burning is minimal. Four (4) to seven (7) bulk tank deliveries of liquid waste and one (1) to two (2) truck loads of containers and/or roll offs are received daily on average. Daily volume received averages between 25,000 to 50,000 gallons. Approximately, two (2) to four (4) truck loads of drums containing the filter sludge, tank sludge and other ancillary waste material (an aggregate of 8,000 to 16,000 gallons) are shipped from the site annually, if not processed through the plant.

In addition to the above, up to 17 trucks per day of transshipments related to transfer station activities are received and/or shipped.

Figure B-1 shows the on-site traffic pattern. All roads are two-way. Waste delivery trucks are restricted to the entrance road from Elm Street, the road between the scale and the LGF/hazardous waste unloading area. Traffic control consists of a manned gatehouse at security gate 1, card access at security gate 2, and various traffic signs (for speed, directional, right of way, caution and flow) throughout the plant.

Fully loaded tankers and trailers of waste have a maximum gross weight of 80,000 lbs. All road surfaces consist of graded and compacted crushed shale as well as road rock base in

high truck traffic areas. Roads are designed to accommodate a gross weight in excess of 100,000 pounds of off-highway earth movers.

Earth movers and frontend loaders involved in the quarry and raw mill operation are generally confined in that area. Twenty (20) to fifty (50) trailer and dump truck shipments of finished lightweight aggregate and raw shale are made from the site daily. Approximately twenty-five (25) hopper bottom rail cars of lightweight aggregate are shipped from the site weekly. Movement of rail cars and the private siding is under control of the company.

Company pickup trucks, cars, maintenance trucks, fuel truck and water trucks have access to all roads on the site.

Figure B-2 shows the off-site traffic patterns. Trucks making deliveries of LLGF/hazardous waste to the facility proceed from the 23rd Street (Watervliet) exit of Interstate Route I-787 west on 23rd Street in the Town of Watervliet 0.10 miles to Broadway Avenue, then north 0.2 miles on Broadway Avenue to 25th Street. At 25th Street, the trucks proceed 0.5 miles west to Lansing Lane. At Lansing Lane, the trucks proceed north for 0.6 miles to Elm Street. The trucks proceed east on Elm Street to the entrance road to Norlite, 0.15 miles from Lansing Lane.

The route from I-787 to Lansing Lane is a regularly-traveled truck route for trucks serving industry along 25th Street, Lansing Lane and Elm Street.

## 2.0 PROCEDURES TO PREVENT HAZARDS

The following sections describe the procedures implemented at the Norlite LLC (Norlite) to prevent hazards that could otherwise adversely impact human health or the environment.

### 2.1 Applicability

Norlite LLC is a facility that receives, handles and burns RCRA hazardous and nonhazardous waste. The facility accepts F, K, P, U listed wastes and D characteristic wastes. The facility can accept wastes that are coded with the D002 and D003 waste numbers, but the waste cannot actually exhibit the characteristics of corrosivity or reactivity, respectively. Complete information about waste is found in the facility Waste Analysis Plan. As described in Sections 3.4 and 4.6 of this Operations Plan, the storage and processing areas are designed to protect against incidents involving flammable, incompatible and reactive materials.

### 2.2 Equipment Requirements

#### 2.2.1 Internal Communications

Norlite has a warning system with a specific alarm signal consisting of a loud horn to initiate evacuation of all plant areas. Telephones are located throughout the plant to provide internal communication throughout the operating areas of the facility except for the quarry. Cellular telephones with two-way “push-to-talk” functionality are carried by most personnel. In addition to the alarm, the internal telephone system can be used to notify plant personnel as to the emergency's nature and the recommended action plan. From the most remote section of the hazardous waste storage area, an employee could obtain access to the internal/external communication system in less than a minute.

### 2.2.2 External Communications

External communications are managed through the telephone system described above in Section 2.2.1. At no time is there only one employee at the facility. From the most remote section of the hazardous waste storage area, an employee could obtain access to the internal/external communication system in less than a minute. All emergency communication practices are detailed in the facility's Integrated Contingency Plan.

### 2.2.3 Emergency Equipment

Norlite's emergency equipment is listed in the Norlite's approved Integrated Contingency Plan, which is incorporated by reference into the Permit.

### 2.2.4 Water for Fire Control

Norlite's facility has three fire hydrants for use by the fire department in case of an emergency. Norlite is connected to the city of Cohoes water system. Plant water is provided by a pumping system that uses water collected in the quarry. In addition, the Salt Kill, which crosses Norlite's facility, is a secondary water supply, which could be utilized in an emergency situation.

### 2.2.5 Testing and Maintenance of Equipment

Norlite's safety and emergency equipment is inspected to insure proper operation during emergency. The facility Security and Inspection Plan identifies the items inspected, the problems inspected for and the frequency of the inspection.

## 2.3 Aisle Space Requirement

6NYCRR Subpart §373-2.3(f) requires that a facility maintain aisle space sufficient to allow the unobstructed movement of emergency equipment and personnel in case of an emergency. Aisle space of, at least, thirty (30) inches between rows of containers will be

maintained. The proposed stacking pattern is found on revised Drawing NY003-2475-1 and NY003-3008. Containers will not be stacked more than two pallets high.

#### 2.4 Integrated Contingency Plan

Norlite has made arrangements with local representatives in an effort to coordinate responses to emergency situations and to educate the response agencies on the particular hazards posed by the facilities. To facilitate a response to any emergency, Norlite will maintain an access road from the Northwest section of the property, coordinate portable radio frequencies access and provide detailed facility maps and updates as required. A detailed description of those arrangements is set forth in the Integrated Contingency Plan, which is incorporated by reference into the Permit.

Norlite has also made arrangements with West Central Environmental, Inc. to act as emergency response contractors to handle an emergency incident involving hazardous waste that cannot be reasonable handled internally. The details of that arrangement are described in the Integrated Contingency Plan, which is included incorporated by reference into the Permit.

#### 2.5 Preventive Procedures, Structures, and Equipment

6NYCRR Subpart §373-1.5(a)(viii) requires that the applicant provide information on the procedures that will be taken to prevent accidents during loading and unloading operations, procedures to prevent undue contamination from the surface water runoff from hazardous waste handling area, procedures to prevent groundwater contamination, procedures to mitigate the damages from an equipment failure or power outage and procedures to prevent undue exposure of personnel to hazardous waste. This information is provided below.

##### 2.5.1 Unloading Operations

Loading operations at the facility involve intermittent loading of containers for off-site disposal and loading/unloading of hazardous waste containers shipped from generators to Norlite. Containers are loaded/unloaded at the LLGF storage area using a forklift. Containers are

managed under the Containerized Waste Management Plan presented in Appendix 1. During loading/unloading operations, spills are unlikely. In the event of an accident, however, the material will be contained with absorbent booms and pads or other absorbent materials, in addition to the loading/unloading area containment trench. Contaminated materials will be collected and affected areas of the facility and contaminated equipment will be decontaminated. Spilled liquids that enter the containment trench are collected and treated on-site.

LLGF that is received in bulk via tank trucks and tank trailers is unloaded in the Loading/Unloading Areas # 1 and #2. The vehicles back into Loading/Unloading Areas #1 or #2 which provides secondary containment for the operation. Prior to delivery, the transporter must certify that he understands the Norlite delivery and operating procedure as described in the Security and Inspection Plan. All LLGF unloading operations are subject to the following LLGF unloading regulations, which are posted in the area:

#### LLGF UNLOADING REGULATIONS

- NO UNLOADING WITHOUT NORLITE REPRESENTATIVE PRESENT
- NO SMOKING
- PARK IN DESIGNATED AREA
- TURN OFF ENGINE
- SET BRAKES
- SET WHEEL CHOCKS
- SECURE GROUND TO VEHICLE
- OPEN TRAILER TANK VENT BEFORE UNLOADING
- DO NOT REMOVE GROUND FROM VEHICLE UNTIL:
  - HOSES ARE DISCONNECTED AND SECURED
  - TRAILER TANK VENTS ARE CLOSED
  - YOU ARE READY TO LEAVE THE AREA
- DO NOT START ENGINE UNTIL YOU ARE READY TO LEAVE AREA

The mechanisms present in the tanks to prevent overfilling are described in Section 4 of the Operations Plan.

#### 2.5.2 Runoff

Norlite's hazardous waste handling areas are not within a 100-year flood plain. Norlite has, however, taken precautions to handle surface water runoff from the hazardous waste

handling areas. Norlite's runoff control system for its container storage area is described in Section 3.0 and its runoff control system for its tank storage area is described in Section 4.0.

### 2.5.3 Water Supplies

Norlite has taken precautions to prevent contamination of the surface water and groundwater.

Groundwater contamination is prevented by performing transfer operations within secondary containment areas. The container storage area and loading/unloading areas are constructed of concrete and treated with chemical resistant coating to contain spills. A roof is provided over the Loading/Unloading Area #1 and the Solids Processing Building to divert precipitation. Similarly, a secondary containment system and precipitation diversion roof is provided for the tank pump and control valve area. Descriptions of the spill containment controls for the container storage area and for the tank storage area including a complete description of the design and construction of the LLGF storage and handling system are presented in Sections 3.0 and 4.0.

The soils underlying the tank storage area including the unloading area, container storage area and containment dike are comprised of a clay liner with a maximum permeability rate of  $1E-07$  cm/sec. The permeabilities of the soils have been laboratory tested. The results of those tests and a discussion of the site geology are included in Norlite's Part 360 application for the additional tank storage that was submitted to the DEC. Additional copies of that application will be submitted upon request.

### 2.5.4 Equipment and Power Failure

Power failure will not cause a release of hazardous waste or materials. In the event of power interruption, magnetic switches controlling all LLGF pumps at the storage area will release causing LLGF flow to stop. The pumps must be restarted manually.

In case of an equipment failure or power outage which does result in the release of hazardous waste, Norlite's emergency coordinator, will activate implement Norlite's Integrated Contingency Plan.

#### 2.5.5 Personal Protective Equipment

Norlite personnel are protected from undue exposure to hazardous waste and hazardous materials. Norlite's personnel protective equipment is described in the emergency equipment provisions of the Integrated Contingency Plan. The personal use of the protective equipment is covered by Norlite's Personnel Training Plan in which is incorporated by reference into the Permit. Norlite's personnel training program satisfies both the requirements of 6NYCRR Subpart §373-2.2(h) and the requirements of the Mine Safety and Health Administrative Standards of 30 C.F.R. Part §46.

### 2.6 Prevention of Reaction of Ignitable, Reactive and Incompatible Wastes

#### 2.6.1 Precautions to Prevent Ignition or Reaction of Ignitable or Reactive Wastes

Norlite does not receive or store reactive or corrosive waste. The procedure for acceptance of all waste is described in the Waste Analysis Plan. This plan will prevent storage of reactive or incompatible wastes at the Norlite facility. Waste analysis testing at Norlite is performed on each delivery prior to unloading to ensure compatibility as outlined in the Waste Analysis Plan.

The main safety concern posed by Norlite's storage operations is the potential hazard posed by an accidental ignition of the LLGF. Ignitable wastes are stored only in the following areas of the Plant: LLGF storage tanks and container storage area at the LLGF unloading station.

Norlite prevents the accidental ignition of LLGF by requiring the use of grounding and/or bonding cables during material transfer to prevent static electricity build up and discharge, by venting vapors directly to the kilns, and by displacing oxygen in the tank headspaces with a nitrogen blanket. The particulars of the tank design features and the management practices aimed at preventing accidental ignition are described in Section 4.0. During container transfer operations to tanks, in the area shown in Drawing NY003-3008, containers are grounded with grounding cables to prevent accidental ignition.

#### 2.6.2 General Precautions for Handling Ignitable or Reactive Wastes and Mixing of Incompatible Wastes

To prevent the mixing of incompatible wastes, Norlite performs a compatibility analysis on a representative sample from all shipments. Only those deliveries found to be compatible with the current LLGF in the storage tank into which the LLGF is to be accepted and unloaded will be accepted. The details of Norlite's waste analysis procedure including its compatibility test are set forth in the Waste Analysis Plan. Containers are stored in such a manner as to segregate incompatible wastes as outlined in the Containerized (Drummed) Waste Management Plan Appendix 1

#### 2.6.3 Management of Ignitable or Reactive Wastes in Containers

Measures to prevent accidental fire and explosion of ignitable waste include the proper storage of containers, providing proper secondary containment, area ventilation, and posting appropriate warning signs.

Prior to storage, each container is sealed to prevent precipitation from entering the drum. The containers are labeled to identify the contents of the container and the date wastes were generated. Container storage areas are required to be no closer than fifty (50) feet to the nearest property boundary. Norlite's container storage area is located 500 feet from the closest company property line.

#### 2.6.4 Management of Incompatible Wastes in Containers

Norlite does not receive or store reactive or corrosive waste. The procedure for acceptance of all waste is described in the Waste Analysis Plan. This plan will prevent storage of reactive or incompatible wastes at the Norlite facility. Testing at Norlite is performed on each delivery prior to unloading to ensure compatibility as outlined in the Waste Analysis Plan.

#### 2.6.5 Management of Ignitable or Reactive Wastes in Tanks

Norlite prevents the accidental ignition of LLGF by requiring the use of grounding and/or bonding cables during material transfer to prevent static electricity build up and discharge, by venting vapors directly to the kilns, and by displacing oxygen in the tank headspaces with a nitrogen blanket. The particulars of the tank design features and the management practices aimed at preventing accidental ignition are described in Section 4.0. During container transfer operations to tanks, in the area shown in Drawing NY003-3008, containers are grounded using grounding cables to prevent accidental ignition.

#### 2.6.6 Incompatible Wastes in Tanks

To prevent the mixing of incompatible wastes, Norlite does a compatibility analysis on a representative sample from the shipment. Only those deliveries found to be compatible with the current LLGF in the storage tank will be accepted. The details of Norlite's waste analysis procedure including its compatibility test are set forth in the Waste Analysis Plan.

### **3.0 MANAGEMENT OF WASTES IN CONTAINERS**

The following sections describe the management of wastes in containers at the Norlite LLC (Norlite). Please refer to Section 1.3 for the container storage locations, waste types, container specifications and containment area capacities. The list of authorized hazardous waste codes is found in the Waste Analysis Plan.

#### **3.1 Container Management**

The truck unloading/containment and container storage areas are shown in Drawings Nos. NY003-3008, NY003-3319 and NY003-2475-1. The container capacity in the container storage areas includes all hazardous waste, nonhazardous waste and raw material containers/rolloffs.

The tanker staging area is used for staging waste tankers and trailers prior to unloading. This area is also used for transportation-related temporary storage and/or transfer activities in compliance with § 372.3(a)(6) and (7). This area is not used for transfer of drums between trucks.

Norlite accepts drums for treatment, storage or disposal at other off-site permitted TSD facilities. Norlite therefore also functions as a transfer facility for facilitating movement of waste to other permitted treatment facilities. Truck-to-Truck drum transfers can only take place in unloading areas #1 or through the solids processing building as shown in Drawing NY003-2475-1.

Hazardous waste that is physically solid can be stored on the concrete pad on the west side of the solids processing building. This is strictly for hazardous waste that is being shipped off-site to another TSD facility.

The types of transfer operations practiced by Norlite are covered in more detail in Norlite SOP #6-001, "TRANSFER STATION SCENARIOS PRACTICED AT NORLITE", located in Appendix 2 of this Operations Plan.

Norlite has provisions for:

- 1029 square foot container storage area in the Drum Processing Building (9,900 gallons capacity) suitable for storage of 180 drums
- 1440 square foot container storage area in Loading/Unloading Area #1 (4,785 gallons capacity) suitable for storage of 87 containers

The tanker staging area can also be used to store roll-offs. This area is 200 feet by 60 feet, and has space for staging up to 13 trucks, tanks wagons and/or roll-off containers.

All drums received or used are of the removable head type or bung hole top openings. Drums received from off-site generators are unloaded and stored in the Drum Processing Building or Truck Unloading Area #1 (see Drawing No. NY003-3008). During times that drums are being stored in the Unloading Area #1 only one truck will be parked in that unloading area.

The drum stacking pattern for the maximum arrangement of drums in each area is shown in Drawing No. NY003-2475-1. Drums are stacked no more than 2 tiers in height. The pallets will only be arranged as shown on Drawing No. NY003-3008 regardless of the size of the containers on the pallets.

The contents of the drums are transferred to the LLGF tanks in the Drum Processing Building shown in Drawing NY003-3008. Containerized wastes are transferred to the LLGF tanks using a vacuum transfer line to Tank 200A or are pumped onto a truck and subsequently transferred to another tank other than 200A. All drums are kept closed except when adding or removing material. The types of containerized wastes managed through this process are liquid and semi-solid materials including but not limited to oily sludges, tank bottoms, partially-cured paint and varnish materials, sorbents contaminated with organic materials and viscous resins. This process is used for wastes generated on-site and for those received from off-site.

The containers are off-loaded at Unloading Area #1 or directly into the Drum Processing Building shown in Drawing NY003-2475-1. Space is available for two (2) container trucks at

the Drum Processing Building and space is available for (2) container trucks Unloading Area #1. The trucks will backup to a point where the rear door opens over the containment structure. Unloading Area #1 is authorized for storage of a single row of palletized containers on the north side of the containment area. Tank Wagons may also be parked in Unloading Area #2 as shown in Drawing NY003-2475-1. In the event any spill does occur, the spill is contained, and will be promptly remediated with the spill control equipment described in the Integrated Contingency Plan.

### 3.2 Containers with Free Liquids

The container storage areas are designed and operated with the proper secondary containment, ventilation, vapor control and fire suppression. Descriptions of the container storage areas square feet and secondary containment are summarized in the table below.

<u>Storage Area</u>	<u>Container Capacity</u>	<u>Capacity Gallons</u>	<u>Drawing No.</u>	<u>Area (Sq.Ft.)</u>	<u>Containment Volume (Gals)</u>	<u>% of Required Containment</u>
Truck Unloading Area #1	87 (55 gal drum equivalent)	4,785	NY003-3008 NY003-2475-1	1,440	9,048	1891 *when used for drum storage
LLGF & Solids Processing Bldg.	180 (55 gal drum equivalent)	9,900	NY003-3008 NY003-2475-1	1,029	2,042	194

The Container Capacity is based on 55-gallon drums. The total volume Capacity is based on the maximum number of 55-gallon drums that can be stored in the storage area. Although most containerized waste received and stored at the facility is in 55-gallon drums, Norlite also receives waste in containers with capacities of 5, 15, and 30 gallons. 85-gallon overpacks are also used to manage smaller damaged or leaking containers. While the Container Capacity listed in the table above may be exceeded if the facility is storing a large number of smaller containers, the total volume Capacity will not exceed the volume listed above.

### 3.2.1 Basic Design Parameters, Dimensions and Materials of Construction

The Drum Processing Building is separated from the Loading/Unloading Area #1 by a 3.5 inch high concrete berm with a scupper providing overflow to the Loading/Unloading Area #1. It is constructed of reinforced concrete with a design strength of 4,000 lbs/in<sup>2</sup> and sealed to the existing slab.

The area is pitched toward the scupper as shown in Drawing NY003-3008. The drum storage area is coated with Protectoline 900 floor finish (or its equivalent), which is a protective phenolic coating. It is applied to the concrete slab and to the curbing at a thickness of 3/32" in accordance with the manufacturer's recommended procedure. Protectoline 900 floor finish has excellent solvent and abrasion resistance and good weathering characteristics. Selection data of the product is included in Appendix 3. Details of the joints on the concrete pad, including both the truck unloading/containment and drum storage areas, are given on Drawing NY003-3008. A urethane sealant is used in the joints, SIKAFLEX-1(a) elastic sealant, a copy of the technical data is found in Appendix 4. The sealant has short-term resistance to organic solvents and it is compatible with the types of liquids delivered to Norlite.

### 3.2.2 Description of How Design Promotes Drainage

The current pad is presently in good condition, free of any gaps, holes or cracks. The scupper constructed in the curb between the drum storage area and the truck unloading/containment storage area allows any large spills (greater than 340 gallons) to overflow into the truck unloading/containment area providing tertiary containment. The pad is inspected daily as discussed in Security and Inspection Plan to insure that it remains intact and in good condition. All drum storage areas as well as the truck unloading/containment area and unloading pumps are covered by a roof to preclude collection of rainwater in these areas.

### 3.2.3 Capacity of the Containment System

The containment capacity of each truck Loading/Unloading Areas 1 and 2 are 9,048 gallons and 22,991 gallons, respectively. Each area provides greater than 110% containment of the largest volume tank truck received, 6,500 gallons or tractor/ trailer rig received (80 drums x 55 gal = 4400 gals). Secondary containment calculations for storage areas are provided as an attachment to the Part 373 Permit.

### 3.2.4 Provisions for Preventing or Managing Run-on

Precipitation run-on is prevented from entering all containment areas by the presence of a 3-1/2 inch curb at the perimeter of the storage area. In addition, the land surrounding all containment area is graded to encourage drainage away from the area. Run-off is prevented from leaving the containment area by the 3-1/2 inch curb at the perimeter of the storage area.

### 3.2.5 Accumulated Liquids

All containment structures within the storage areas are checked daily. If liquids are detected within the storage area, the source is immediately corrected and liquids removed, ensuring that the maximum containment capacity is available in the unlikely event that another spill or leak should occur. All liquids removed from a secondary containment system are sampled and handled as a hazardous waste in accordance with the Waste Analysis Plan.

## 3.3 Containers without Free Liquids

The Tanker Staging Area is authorized for the transportation-related temporary storage of roll off containers that contain hazardous waste that do not have free liquids. The area can hold up to 13 roll offs, which have a maximum individual capacity of fifty (50) cubic yards. The total maximum capacity of roll off storage is 650 cubic yards. Details of the area are found on Drawing NY003-3319.

### 3.4 Requirements for Ignitable or Reactive Wastes and Incompatible Wastes

The location of all storage areas is more than fifty (50) feet from the facility property line.

Using procedures described in the Waste Analysis Plan Section 4.3.3, Norlite does not store incompatible wastes or wastes that are incompatible with the containers in which they are stored.

## 4.0 MANAGEMENT OF WASTES IN TANKS

The following sections describe the management of wastes in tanks at the Norlite LLC (Norlite).

Please refer to Section 1.3 for the permitted tank storage area, tanks and permitted capacities. Each tank is authorized to store all hazardous waste (LLGF) identified as acceptable in the facility's waste analysis plan.

### 4.1 Existing Tank Systems

The following sections provide a description of the tanks systems existing at the Norlite LLC (Norlite).

#### 4.1.1 Assessment of Existing Tank Systems

Norlite uses an independent engineer review the integrity testing on the tanks using 6 NYCRR 373-2.10(b) as reference.

Tank thickness measurements, if possible, will be conducted when the tanks are emptied and cleaned. In the past, measurements were made on the inside of the tank using an ultrasonic thickness gage such as Panametrics Model 5230. The glass coating on the inside of Tanks 300, 400, 500 and 600 impact the accuracy of the foregoing measurement device. It would not be possible, however, to take thickness measurements from the outside of the tank since the polyethylene liner system and clay cover system would have to be disturbed to expose the tank. Excavation of the tank would jeopardize the integrity of these systems. The location of the testing sites is shown on Stetson-Harza sheet, Appendix 5.

The following table shows the current data of each tank at the time of application:

TANK #	DIAMETER	SIDE LENGTH	SHELL THICKNESS	MAX. CAPACITY (GALS.)
300	10'11"	40'10"	>3/8"	27,903
400	10'11'	40'10"	>3/8"	27,903
500	10'11'	40'10"	>3/8"	27,903
600	9'2"	39'3"	>3/8"	18,940
100A	11'0"	11'0"	1/4"	9,491
100B	11'0"	11'0"	1/4"	9,491
100C	11'0"	11'0"	1/4"	9,491
200A	11'0"	11'1"	3/4"	10,663
200B	11'0"	11'0"	1/4"	9,491
200C	11'0"	11'0"	1/4"	9,491
101A	5'	7'6"	1/4"	1,266
101B	5'	7'6"	1/4"	1,266
102A	5'	7'6"	1/4"	1,266
102B	5'	7'6"	1/4"	1,266

\*All dimensions are nominal

Daily pump inspections are scheduled as shown in Security and Inspection Plan, Section 3.5.2. The LLGF storage area including pumps is inspected three times each shift as indicated on the Trunnion Operators Shift LLGF Inspection Report.

The piping and instrumentation diagram for the LLGF system is shown Drawings NY003-1311, NY003-1312, NY003-1314, NY003-1315, NY003-5010, NY003-1317 and NY003-1903. Each pair of tanks in the Tank Farm Building (e.g. 100C and 200C) have identical loading, unloading, and control systems. The compatibility of the solvents with the carbon steel piping and the tanks is specified in the attached compatibility charts from "Technology for the Storage of Hazardous Liquids," NYSDEC January 1983 found in Appendix 6.

The tanks are filled with LLGF by off loading trucks at the truck unloading areas. For Tanks 200A, B, C and 100A, B, C; a high level switch on each tank shuts down all the transfer pumps if the switch is activated. The level switches are set to activate when the level reaches 12 inches from the top of the tank. Each tank is equipped with a level indicator, pressure and vacuum rupture discs and nitrogen blanketing.

For Tanks 300, 400, 500 and 600, there is a network of leak detection piping that was installed. This system consists of perforated drain pipes wrapped with filter fabric installed above each of the HDPE geo-membranes. The lower set of drain pipes discharge to the secondary spill containment area as shown. The liner is sealed to the drain pipes at the locations where the pipes pass through the liner. The sealing method is as follows: a prefabricated boot is slipped over the penetrating pipe. The base sheet is welded to the HDPE liner with a fusion welding gun. The boot, also of HDPE, is strapped to the pipe with a butyl seal and a 3/4" stainless steel band. Information on the method as well as further quality assurance data is provided in Appendix 7. The upper set of "tell-tale" drain pipes are installed as shown on NY003-5430. These pipes do not discharge to the spill containment slab but instead are used to pump out any liquid, which collects above the upper HDPE geo-membrane.

Tanks 300, 400, 500 and 600 are glass-lined (approximately 1/16 inch) for chemical and corrosion resistance. Glass-lined tanks have been shown to be very resistant to a variety of chemicals in a wide range of concentrations including solvents. For any failures in the glass lining, the 3/8" carbon steel shell will provide sufficient protection. Reported corrosion rates for solvents being stored with carbon steel are between 0.002 and 0.02 in/yr ("Corrosion Data Survey," 1967 Edison, G.A. Nelson, National Association of Corrosion Engineers). Using a median value of 0.011, and the assured shell thickness, the service life is calculated and presented in Appendix 8.

Corrosion to the external shell of the tanks will be prevented by the application of a corrosion resistant coating. Surface preparation was accomplished by sandblasting per SSPC-SP6 (commercial blast) prior to coating. Two coats of 5-7 mils each of Carbomastic 15 were then applied. The tanks were inspected for complete coverage by a registered professional

engineer. The specifications for Carbomastic 15, an aluminum epoxy mastic manufactured by Carbolite are found in Appendix 9.

A cathodic protection system was installed for additional corrosion protection. This system is shown on Drawing NY003-5430. The material in which the tanks are imbedded is also slightly alkaline, a condition which further inhibits corrosive activity. The clay cap and liner system also prevent groundwater from being introduced to the medium surrounding the tanks. The entire installation as described provides a complete system of corrosion protection and prevention. Detail is provided in Appendix 10. To protect against static electric charges, all the tanks were grounded in a loop, thereby reducing the charge separation.

A piping and instrumentation diagram showing the storage tanks, instrumentation, and valving is shown on Drawing NY003-1317. Inlet and outlet valving are manually operated except for the fire safe valve and solenoid valve on the tank outlet.

The tanks were tested for tightness prior to and after back filling with a soap test after pressurizing the tanks. A visual test was done on the external coating prior to backfilling. The cathodic protection system was also tested in accordance to the manufacturer's recommendation.

#### 4.2 New Tank Systems

RESERVED

#### 4.3 Secondary Containment for Tank Systems

The Tanks 300, 400, 500 and 600 are imbedded in two (2) feet of coarse sand compacted with a vibrating plate to provide uniform support along the entire length of the tank as shown on Drawing NY003-5430. Beneath the sand is an impermeable liner consisting of the following components that were installed as follows:

- one (1) 40 mil. HDPE geo-membrane.

- one (1) layer consisting of 6"-12" compacted clay and sand.
- one (1) 40 mil HDPE geo-membrane.
- one (1) layer consisting of 12" of clay installed in two (2) 6" lifts compacted to  $1 \times 10^{-7}$  cm/sec.

This system provides three (3) impermeable barriers between the tank outer shell and the area beneath the compacted clay liner. The bottom of the excavation as well as the clay liner and HDPE geo-membranes are sloped towards the pump containment slab. The liner system was installed with seams necessary to connect the sections of geo-membrane. The liner system is extended upward on the sides and ends of the tanks and extended to connect with the pump containment slab.

The clay cover was installed to extend beyond the ends and sides of the tank and slopes down to the ground to prevent lateral transfer of rainwater towards the tanks. The clay cover is shown on Drawing NY003-5430.

Norlite has installed secondary containment on Tanks 300, 400, 500 and 600. The secondary containment consists of an impermeable liner which discharges to a concrete pad (the pump pad) that has been coated with an impermeable coating. That sealant is the Phenoline 300 sealant, which is the same sealant that has been used to coat the truck unloading pad.

The 100-series and 200-series tanks are above ground tanks that are housed in a concrete containment system with a capacity of 57,289 gallons. The required containment capacity is 9,271 gallons based on the largest tank (200A) housed within the structure. The floors are sealed with Phenoline 300 sealant.

The 101-series and 102-series tanks are above ground tanks that are also housed within a concrete containment system. The containment capacity is 5,214 gallons. The required containment capacity is 1,266 gallons based on the size of the four (4) tanks housed within the structure. The floors are sealed with Phenoline 300 sealant.

#### 4.4 Double-Walled Tanks/Diked Tanks

RESERVED

#### 4.5 General Tank Operating Requirements

Tank level for all tanks is indicated in gallons by an ultrasonic or radar level indicator with digital readouts. The level range is 12 inches off the bottom to full capacity. Since the agitators do not create any significant waves or splashing, the agitators do not interfere with the tank level indicators. Data sheets for the indicators are found in Appendix 11. Tank pressure is indicated by a pressure gauge mounted on the vent of the tank. Pressure relief is provided by rupture discs. Tank 200A tank level is determined by manual gauging and sampling. Tank Sampling is described in SOP #4-007.

A high level alarm switch is included in the level indicator for Tanks 100A,B,C and 200A,B,C. The switch will operate when the tank level is 12 inches from the top. The switch actuates a solenoid valve in the discharge pipe of these tanks. For Tank 200A, the vacuum pump automatically shuts off when the tank is full due to lack of air flow.

For Tanks 300, 400, 500 and 600, a fire safe valve is in the discharge pipe from the tank. This is a spring-loaded gate valve with a 180°F fusible link that actuates at low pressure.

Each tank (100A,B,C; 200A,B,C; 300-600) is equipped with a rupture disc. Tanks 100A,B,C and Tanks 200B,C have 6-inch discs that fail at 20 psig pressure and 8 inches H<sub>2</sub>O vacuum. Because it is a vacuum vessel, Tank 200A is equipped with a 6-inch disc that fails at 20 psig only. Tanks 300, 400, 500 and 600 use 3-inch discs that fail at 20 psig pressure and 8 inches H<sub>2</sub>O vacuum. And Tanks 101A,B and 102A,B have 6-inch discs that fail at 20 psig pressure and 2 psig. The nitrogen vent from the tank is directly piped to the aggregate kiln eliminating any atmospheric emissions during normal operation. The tanks vent to the kiln at pressures greater than 6 psig. During tank filling operations venting is provided to the kiln

whereas when the tank is emptied during fueling for the kiln, nitrogen is supplied to the tank. Rupture disc certifications are found in Appendix 12.

For kiln fueling operation from Tanks 100B, 100C, 200B and 200C, the manual valve on the tank outlet is opened and the outlet pump is turned on. For Tanks 300, 400, 500, and 600, the manual valves on the kiln supply line and tank return are adjusted to provide the proper LLGF flow to the kiln and return to the top of the tank.

The following table indicates the circulation and agitation ability of each tank:

<b>TANK #</b>	<b>Agitators</b>	<b>Recirculation</b>	<b>Recirculation by return from kilns</b>
300	yes	Yes	yes
400	yes	Yes	yes
500	yes	Yes	yes
600	yes	Yes	yes
100A	yes	Yes	yes
100B	yes	yes, from the bell*	yes
100C	yes	yes, from the bell*	yes
200A	yes	Yes	yes
200B	yes	yes, from the bell*	yes
200C	yes	yes, from the bell*	yes
101A	yes	Yes	yes
101B	yes	Yes	yes
102A	no	Yes	yes
102B	yes	Yes	yes

\*The tank has a suction line at the very bottom of the tank so that there is no static volume of material in the tank when recirculated

For Tanks 300, 400, 500 and 600; if there is a breach in the first liner, a leak would be detected by liquid exiting onto the containment slab from the tell-tale pipe under the tank. This pipe is a 4" perforated drain pipe that is positioned under the center of the tank and directly on top of the clay liner. The perforations face downward, and any liquid leaking from a tank and through the synthetic liner enters the pipe and runs out onto the pump containment slab. The flow capacity of the four inch perforated PVC drain pipe under the Tanks 300, 400, 500 and 600 has sufficient flow capacity to handle small leaks and only serves to provide indication of the beginning of a tank failure. For catastrophic failure of a tank, the sloped clay and polyethylene liner system directs large flows to containment areas. To prevent clogging, 1-inch gravel was installed as a covering for the drain pipe. The pipes are wrapped with a geotextile filter fabric to prevent sand from clogging the drain pipes. The PVC pipe between the tanks and the spill containment slab is non-perforated as shown on NY003-5430.

#### 4.6 Requirements for Ignitable or Reactive Waste Storage in Tanks

Norlite has not found LLGF to be reactive but it is ignitable. There are no sources of ignition such as an open flame and no smoking is permitted in the vicinity of the storage tanks. All electrical devices in the area are explosion proof, Class 1, Division 1 and 2, as required. Oxygen is excluded from the tank by the nitrogen blanketing system and all vapors are vented from the tank to the aggregate kiln eliminating any vapor discharge or build-up around the tanks. All the tanks are grounded to prevent the generation of static electricity. The inlet fill pipe and the mixing nozzles both direct liquid entry to the bottom of the tank eliminating any falling liquid from a top entry nozzle that could produce static free charges on the surface of the liquid. The tanks are located more than 50 feet from the facility property line and from the nearest building as requirements in the National Fire Protection Association's "Flammable and Combustible Liquids Code" (NFPA30).

The specifications for joints, flanges and threaded connections are presented in the piping specification in Appendix 13. For threaded connections, the sealant is teflon tape or paste. Its compatibility with solvents shown in Appendix 6. Flanges are joined with compressed gaskets, Garlock Style 8748. The compatibility of this material with solvents is shown in the attached Garlock "Guide for Choice of Gasketing" as Appendix 14.

The compatibility of the tanks with solvents is shown in the charts referenced above. In addition, corrosion charts for solvents and carbon steel are attached from "Corrosion Data Survey," 1967 Edition, G.A. Nelson, National Association of Corrosion Engineers as Appendix 15.

#### 4.7 Requirements for Incompatible Waste Storage in Tanks

Due to the prescreening process described in the Waste Analysis Plan, Section 4.3.3, Norlite does not store incompatible wastes or wastes that are incompatible with the storage tanks in which they are stored.

#### 4.8 Tank Inspection

In addition to the secondary containment provided by the liners under the Tanks 300, 400, 500 and 600, the LLGF building, used for Tanks 100A,B,C and 200A,B,C, also serves as a tertiary containment system for the outside tanks. In the event that the secondary containment system fills, liquid will overflow through a pipe to the LLGF storage building. The containment volume of this LLGF building is 33,940 gallons. This volume is sufficient to hold the entire contents of any LLGF tank that should fail.

Inspection of spill containment facilities will be conducted as follows:

Daily - The spill containment for loading/unloading areas, container sampling areas and drums stored in the unloading areas will be inspected for any spills.

##### 4.8.1 Tanks without Secondary Containment

RESERVED

#### 4.9 Tank Spills and Leakage

In the unlikely event of an emergency arising from a tank spill or tank leakage, the procedures found in the Integrated Contingency Plan, Section II will be followed. Norlite personnel will act to minimize or remove the threat of any tank failure. As described in Section 4.3, the facility is designed to contain any spill of material from the tanks and prevent release to the environment.

#### 4.10 Closure and Post-Closure Care

All LLGF stored in the tanks will be incinerated in the kiln, or, alternatively, pumped into tankers and transported to another permitted facility for treatment and/or burning as fuel. All LLGF sludge will be removed from the tanks by means of shoveling and placed into 55-gallon drums by a qualified environmental contractor. The material is then shipped off-site for proper treatment and disposal.

Full detail of closure activities is found in the facility's Closure Plan.

## **5.0 MANAGEMENT OF WASTES IN SURFACE IMPOUNDMENTS**

Reserved

## **6.0 MANAGEMENT OF WASTES IN LANDFILLS**

Reserved

## 7.0 MANAGEMENT OF WASTES IN BOILERS AND INDUSTRIAL FURNACES

The following sections describe the management of wastes in industrial furnaces at Norlite LLC (Norlite). The permit requirements for operation of the industrial furnaces can be found in Schedule 1 of Module 1, Exhibits A and E.

Location/Identification Number	Waste Types and Hazardous Waste Codes	Physical Form of Waste	Design Thermal Capacity	Waste Source
Kilns 1 and 2	All hazardous waste described in the Waste Analysis Plan (LLGF)	Liquids blended with sludges and semi-solids	62 MM BTU/Hr	Wastes received from offsite generators and wastes generated onsite as described in the Waste Analysis Plan

### 7.1 Design and Operation

Raw materials are quarried on-site and are conditioned by crushing and screening. The conditioned shale feed is stored in a silo and fed to the kiln via a gravimetric conveyor. Calcination of the shale occurs at a product temperature of approximately 1700°F to 2000°F. Within this temperature range the shale reaches a point of incipient fusion where it is in a semi-plastic state, which allows internal gases to expand, thereby creating voids. As the expanded product leaves the burning zone it begins to cool. Cooling continues as the product drops out of the kiln into a clinker cooler. The cooled vitreous clinker is then discharged and stockpiled. The shale feed rate limit to the kiln is 22 tons per hour.

Heat is supplied to the kiln by firing fuels as described in the table below. All fuel is injected countercurrent to the product flow through the kiln via burners at the discharge (front) end of the kiln. Virgin fuel oil, specification used oil fuel and comparable fuels are fed from Tanks R1, R2, M1 and M2, located in the tank farm adjacent to Tank 9. This delivery system is

not interconnected to the LLGF delivery system in any way. No hazardous or nonhazardous waste is delivered to the kiln through this system.

<u>Feed</u>	<u>Flow Measurement Instrument</u>	<u>Units</u>	<u>Recorded (manual/auto)</u>	<u>Inst/MRA/HRA</u>	<u>Data Stored</u>	<u>AWFCO Valve</u>
LLGF/Waste Fuel B	Micro Motion	GPM	Auto	MRA/HRA	Yes	Yes
Spec Used Oil	Micro Motion	GPM	Manual	Begin/End of Shift	Yes	No
Off-Spec Used Oil	Micro Motion	GPM	Auto	MRA/HRA	Yes	Yes <sup>4</sup>
Waste Fuel A	Micro Motion	GPM	Auto	MRA/HRA	Yes	Yes <sup>4</sup>
Natural Gas	NA	Therms	Auto <sup>1</sup>	Monthly <sup>2</sup>	Yes	No
Diesel Fuel/ Kerosene/Comparable Fuels/ Fuel Oil #2, #4, #6	Micro Motion	GPM	Manual	Begin/End of Shift <sup>3</sup>	Yes	No
Water	Roto Meter	GPM	Manual	NA	Yes	No
Vapors	NA	NA	No	NA	NA	No
Air: Primary Atomization	Both Use Rosemount Pressure Transmitter	PSIG PSIG	NA Auto	Inst HRA	No Yes	No Yes


Note: NA = Not Applicable

- 1- Metered by utility company
- 2- Includes Kiln 1 & Kiln 2
- 3- Depends on feed through on-spec or off-spec feed line
- 4- AWFCO valve only applies when Carbon Monoxide (CO) is over 500 ppm

The various feed streams to the kiln are delivered based on the table below:

<b>Feed</b>	<b>Storage</b>	<b>Kiln Delivery</b>
LLGF/Waste Fuel B	100A, 100B, 100C, 200A, 200B, 200C, 300, 400, 500, 600	Main Burner Assembly
Spec Used Oil	M1, M2, R1, R2	Oil Pilot
Off-Spec Used Oil	Tank 9	Main Burner Assembly
Waste Fuel A	Tank 9	Main Burner Assembly
Natural Gas	NA	Main Burner Assembly Natural Gas Pilot
Diesel Fuel/ Kerosene/Comparable Fuels/ Fuel Oil #2, #4, #6	M1, M2, R1, R2	Oil Pilot
Water	NA	Main Burner Assembly
Vapors	NA	Main Burner Assembly
Air: Primary Atomization	NA	Main Burner Assembly

Each kiln has three injection points for these feeds: the main burner assembly, the oil pilot and the natural gas pilot. They are situated in the front end wall of the kiln as shown below:



Typical kiln combustion gas and material retention times are 4 to 5 seconds and 45 minutes, respectively. Draft for the kiln is supplied by a Barrons induced draft fan. Secondary

combustion air is supplied by forced draft fans from the clinker coolers. Secondary combustion air is preheated by passing it through a moving bed of hot product in the clinker cooler.

LLGF is pumped to the kiln's main burner at a maximum rate of 10.3 gpm. The facility has demonstrated and is requesting authorization to increase the maximum rate to 10.5 gpm. Fuel is supplied to the burner nozzle through an inner pipe while atomization air (or steam) is supplied through a concentric outer pipe.

Each kiln is manned on an around-the-clock basis by the burner operator from the kiln control room. The burner operator can monitor critical operating variables from the control room via a computerized data acquisition system (DAS). The burner operator can also make operational set point changes via the computer system. Equipment stop/start circuitry is housed in the kiln control room or in the field via motor control centers. All field instrument signals are processed through an Allen Bradley Programmable Logic Controller (PLC). Information from the PLC is gathered by the DAS and processed into visual information for the use of the burner operator. The PLC is in control of the Automatic Waste Feed Cutoff System (AWFCO) as described below at all times and operates independent of the DAS.

The burner operator is assisted by the kiln field operator and the mechanic who are responsible for activities outside the control room and burner floor area. The kiln field operator and mechanic perform routine inspections, make field only parameter adjustments, and perform routine mechanical maintenance of the kiln and air pollution control systems.

The burner operator in conjunction with the kiln field operator and mechanic make routine system adjustments to maintain the kiln at optimum conditions for the production of light weight aggregate while maintaining the system within the operating window as set forth by the AWFCO system.

In the event an AWFCO operating parameter has an excursion outside the operating window, LLGF is automatically cutoff by the AWFCO system. The burner operator will switch

to an alternate fuel such as natural gas or oil until corrections are made to bring the operation within the operating window.

In the event a non-AWFCO operating parameter has an excursion, the burner operator will attempt to make system corrections to bring the parameter within specification. Should the corrections not bring the parameter within specifications, the excursion will ultimately cause one or multiple AWFCO parameters to trigger the AWFCO system to operate.

In the event of a power failure, all systems shutdown including, but not limited to, LLGF flow, fuel farm feed systems, raw shale feed, main flame, etc. All systems require manual restart. A virgin fuel is fired to bring all operating parameters within the operating window prior to commencing LLGF feed.

The main flame of the kiln is either self-sustaining or sustained by the presence of a virgin fuel pilot. The main flame and the pilot flame are monitored by an electronic eye to have proof positive that a flame exists. In the event of a loss of signal by the electronic eye, the virgin fuel feed to the pilot, the main natural gas valve, the LLGF AWFCO valve, and the used oil feed valve are closed and a manual reset is required to re-establish a proof positive of flame. Should operating parameters fall outside the operating window during a flame failure, a virgin fuel is fired to bring all operating parameters within the operating window prior to commencing LLGF feed.

#### 7.1.1 Kiln Emission Control Systems

Both kilns have identical emission control systems. The systems include both wet and dry emission control devices for the collection and removal of particulate matter, metals, hydrogen chloride (HCl), and other gaseous species. The principal collection mechanisms employed by these devices are sedimentation, condensation, impaction, filtration and interception for particulates and metals, and absorption for HCl and other gaseous species.

Combustion gases and entrained particulates exiting the kiln pass through a mechanical collector, a Barrons multiple cyclone unit (multiclone), to remove large particulate matter. Particulates removed by this device accumulate in a hopper from which they are pneumatically conveyed to the Dust Storage Silos. Dust from these silos is beneficially used in a block mix product.

Gases exiting the multiclone then pass to an air cooler, a closed cycle air to air heat exchanger. Process gases enter the heat exchanger at approximately 900°F and exit at approximately 450°F.

Following the heat exchanger, a three-module baghouse (fabric filter) is provided to remove fine particulates which are entrained in the gas. The baghouse is designed for operation on two modules while the third module is down for maintenance, however, hazardous waste is not fed unless all three modules are online. Hydrated lime ( $\text{Ca}(\text{OH})_2$ ) is continuously fed to the baghouse to enhance particulate removal and help control acid gases. Accumulated particulates and (partially) reacted lime is removed from the filter media by sequentially pulsing a small fraction of the filter bags at a time with compressed air. Particulates so removed accumulate in a hopper from which they are pneumatically conveyed to Dust Storage Silos. Like particulates removed from the multiclone, baghouse dust is beneficially used in a block mix product. A modulating damper located upstream of the baghouse automatically adjusts baghouse inlet gas temperatures (if required) to the range of 375°F to 400°F ( $\pm 5^\circ\text{F}$ ) by tempering with ambient air.

Immediately downstream of the baghouse is an induced draft fan which draws tertiary combustion air through the kiln, multiclone, heat exchanger and baghouse and provides forced draft to exhaust combustion gases through the wet scrubbers and mist elimination units. Additionally, the fan provides induced draft for a hood installed over the kiln shale feed chute to capture any fugitive emissions emanating from this area.

Two wet scrubbers are provided to capture particulates and to remove acid gases which escape capture/removal in the baghouse. The first is a BECO Venturi (MMV) scrubber. This scrubber is of a rod design which utilizes stainless steel tubes installed in rows across the throat

to provide a series of smaller throats. The intent is to provide the effect of a small venturi throat without incurring the high pressure drop typically associated with conventional high efficiency venturi scrubbers. Further, the tubes provide additional impaction surfaces for enhanced particulate and HCl collection.

Clean water atomization headers are located at the entrance of the scrubber to cool and saturate combustion gases. The scrubbing medium is a sodium carbonate (soda ash) solution which is introduced through nozzles located directly above the venturi module. This solution is recycled through the unit at approximately 200 gpm and, at equilibrium, contains approximately 10% dissolved solids consisting principally of sodium carbonate, sodium chloride and/or sodium sulfate. Scrubbing solution is also injected into the transition segment located immediately downstream of the venturi scrubber.

Excess water/scrubbing solution drains from the venturi exit elbow to a settling/recycle tank. The pH of the solution in the recycle tank is continuously monitored by a pH probe and automatically maintained at a pH of 7.9 or greater by the introduction of a 5% sodium carbonate solution. A portion of the recirculated solution is removed (blown down) from the recycle pump discharge to maintain a stable solids concentration in the system. The blowdown rate ranges between 4 and 20 gpm, depending on the quantity of fuel burned as well as the chloride and sulfur contents. The second scrubber is a (Ducon) polishing scrubber/mist eliminator. This unit consists of a bundle of tubular baffles which are designed to capture droplets of scrubber solution entrained in gases exiting the BECO scrubber. Additionally, a mesh-type mist eliminator is fitted at the top of the unit, immediately preceding the exhaust stack. The mist eliminator is kept clean by a water spray. Finally, scrubbed gases are exhausted to the atmosphere, 120 feet above grade, via a 48 inch diameter stack.

## 7.2 Waste Analysis

The Waste Analysis Plan provides complete detail of the sampling and analysis procedures used to ensure that the LLGF feed complies with the operating limits set by the

facility's Trial Burn. Critical feederate parameters are set for heat input, total halogens and various metals.

### 7.3 Performance Standards and Operating Requirements

The following table displays the operating limits as determined by the latest MACT Comprehensive Performance Test (CPT). The MACT CPT regulations have superseded RCRA Trial Burn testing.

Kiln Operating Parameters	Units	CPT Test Results			How Set	MIN or MAX	Cond. Used	Final OPL
		C2	C1RT	C1A				
<b>Process &amp; CEM Parameters --</b>								
Total (and Pumpable) LLGF Feed	gpm	10.3	10.3	10.5	(a)	MAX	C1A	10.5
Kiln Production Rate (Shale Feed)	tph	22.8	23.6	23.6	(a)	MAX	C2	22.8
LLGF Atomization Pressure	psi	29.6	37.7	35.9	(b)	MIN	C1A	35.9
Back End Temperature	°F	990	895	895	(c)	MIN	C1A	895
Heat Exchanger Exit Temperature	°F	450	434	436	(c)	MAX	C1A	436
Flue Gas Flowrate	wet scfm	35,691	34,425	45,625	(c)	MAX	C1A	45,625
CO Conc. @ 7% O <sub>2</sub>	ppm	41.7	34.5	45.5	(d)	MAX	N/A	100
<b>APCS Parameters --</b>								
Baghouse Inlet Temperature	°F	400	386	383	(c)	MAX	C2	400
Venturi Pressure Drop	in. w.c.	6.1	6.2	8.6	(c)	MIN	C2	6.1
Scrubber Recirculation Rate	gpm	174.7	172.7	171.1	(c)	MIN	C2	174.7
Scrubber Blowdown Rate	gpm	14.6	13.9	14.1	(c)	MIN	C2	14.6
Scrubber Liquid Ph	pH	8.1	8.0	8.0	(c)	MIN	C2	8.1
Scrubber Tank Liquid Level	% Ht.	58.0	56.5	56.7	(c)	MIN	C2	58.0
Scrubber Liquid to Gas Ratio	gal / 10 <sup>3</sup> ft <sup>3</sup>	4.9	5.0	3.8	(c)	MIN	C2	4.9
Lime Feed Rate	lb/hr	250	270	270	(c)	MIN	C2	250
Lime Carrier Fluid Flow Rate	scfm	151.8	150.8	150.1	(c)	MIN	C2	151.8
<b>Constituent Feed Rates --</b>								
Total Chlorine	lb/hr	119.2	93.4	119.2	(c)	MAX	C2	119.2
Total SVM (Cd & Pb)	lb/hr	6.56	1.26	1.68	(c)	MAX	C2	29.3
Total LVM (As + Be + Cr)	lb/hr	6.46	4.74	5.03	(c)	MAX	C2	16.6
Total Pumpable LVM	lb/hr	2.86	0.85	1.17	(c)	MAX	C2	5.55
Total Mercury	lb/hr	0.0109	0.0018	0.0022	(c)	MAX	C2	0.036

- (a) Average of the maximum hourly rolling average for each run
- (b) Based on manufacturer recommendation and Norlite operating experience
- (c) Average of the test run averages. For metals, also based on extrapolation; see Table 4-11 and associated text.
- (d) Regulatory citation

**Table Key: LVM=Low Volatile Metals, SVM=Semivolatile Metals, C1A=Condition 1A, C1RT=Condition 1 Retest, C2=Condition 2**

**Table 4-11 Metal Extrapolation Calculations**

Parameter	Units	Volatile Metals VM	Low Volatile Metals LVM	Semivolatile Metals SVM
Surrogate Metal for the CPT	--	Hg	Cr	Pb
Test Condition Used	--	C2	C2	C2
Average CPT Feed Rate	lb/hr	0.0108	5.63	6.20
Average CPT Emission Rate	µg/m <sup>3</sup>	33.6	36.6	54.5
	lb/hr	1.91E-03	2.05E-03	3.03E-03
Test Average Surrogate SRE	%	82.37%	99.965%	99.955%
MACT standard for LWAKs	µg/m <sup>3</sup>	120	110	250
MACT standard equivalent	lb/hr	0.0164	0.0150	0.0342
90% of the MACT standard	µg/m <sup>3</sup>	108	99	225
Stack Gas Flowrate	dscfm	36,504	36,504	36,504
Stack Oxygen Concentration	%	14.99	14.99	14.99
Extrapolated Feed Rate Limit at 90% of the MACT Standard	lb/hr	0.036	16.603	29.349
<b>Established Feed Rate Limit</b>	<b>lb/hr</b>	<b>0.036</b>	<b>16.6</b>	<b>29.3</b>
Minimum Required SRE to meet the MACT Standard	%	34.781%	99.885%	99.763%

**Note:** The MACT standard and the average CPT emission rate (µg/m<sup>3</sup>) are corrected to 7% oxygen.

#### 7.4 Monitoring and Inspection

The kilns' PLCs, Continuous Monitoring Systems and Continuous Emission Monitoring Systems are interlocked with the automatic waste feed cutoff (AWFCO) systems. All operating parameters are monitored at their required frequencies and are on display in the kiln control room and recorded on the kiln data reports.

Inspection of the kilns is described in the Security and Inspection Plan.

#### 7.5 Closure

Norlite's two lightweight aggregate kilns are cylindrical, horizontally-mounted rotary kilns. The kilns are constructed of steel shells, with a six-inch refractory lining. The system involves piping and intermediate pumping station for feeding waste from the LGF storage tanks

to the kilns, the kilns, a mechanical collector, a heat exchanger, baghouse, a venturi and ducan scrubber for air emissions from the kilns and an exhaust stack.

Since the LGF is filtered prior to burning and due to the very high destruction efficiency of the kilns, there is no remaining hazardous waste residues within the kilns. Therefore, closure procedures associated with closure of the kiln operations will involve the decontamination and dismantling of waste feed lines to the kilns; disposal of contaminated washwaters generated from decontamination procedures; and, definition, excavation and disposal of any contaminated surface soils.

If closure of the hazardous waste energy recovery operations at the kiln occur in accordance with the procedures outlined, the operation of the kiln may continue following closure with the use of non-waste fuel. Thus, dismantling or demolition of the aggregate kilns and their ancillary equipment (i.e., air pollution control equipment, etc.) is not included in the final closure procedures. To indicate successful decontamination of the kiln upon cessation of the use of LGF, the kiln will be operated in a "burnout" mode with only auxiliary fuel fired for an appropriate time period, but not less than four hours, maintaining at least the minimum temperature specified in the permit. This will allow for the combustion of any remaining organic constituents within the kiln system. As soon as practical, allowing for the kiln to properly cool prior to entry, a set of wipe samples (minimum of ten locations scattered throughout the kiln) will be taken. Wipe sampling will involve sampling kiln surfaces exposed to the LGF and/or exhaust gases. Each wipe sample collected will be a 100 sq. cm. sample. Decontamination will be deemed successful if the resulting analytical results for the specified parameters, using appropriate GC methods of analysis in accordance with SW-846, do not exceed regulatory standards in effect at the time of closure.

## **8.0 MANAGEMENT OF WASTES IN CONTAINMENT BUILDINGS**

Reserved

## **9.0 MANAGEMENT OF WASTES IN MISCELLANEOUS UNITS**

Reserved

## 10.0 AIR EMISSION STANDARDS

The following sections describe compliance with the air emissions standards at the Norlite LLC (Norlite).

### 10.1 Air Emission Standards for Process Vents - Subpart AA

RESERVED

### 10.2 Air Emission Standards for Equipment Leaks - Subpart BB

The details for compliance with Subpart BB are provided in Appendix 16 of the Operations Plan. The charts identify the requirements for each piece of equipment that is subject to Subpart BB.

### 10.3 Air Emission Requirements for Tanks, Surface Impoundments and Containers - Subpart CC

#### 10.3.1 Waste Determination Procedures

Norlite does not operate any exempt tanks and presumes that all hazardous waste received contains greater than 500 ppmv. No actual analysis is performed to demonstrate that hazardous waste received or stored is eligible for the exemption. All tanks are operated with Level 2 controls.

#### 10.3.2 Standards for Tanks, Surface Impoundments and Containers

Norlite Corporation (Norlite) operates six vertical above ground tanks, four horizontal covered aboveground tanks, and five other ancillary tanks for a total storage capacity of 155,579 gallons as per 6 NYCRR 373-2.29. These tanks are subject to routine and scheduled inspections as per 6 NYCRR 373-2.29(e)(7)(iii)(a): the fixed roof and its closure devices shall be visually inspected by the owner or operator to check for defects that could result in air pollutant emissions. The closure devices shall be designed to operate such that when the closure device is

secured in the closed position there are no visible cracks, holes, gaps, or other open spaces in the closure device or between the perimeter of the cover opening and the closure device. For the purpose of this inspection, closure devices on the tanks are flanged and the inspection will focus on the flange connection. Overall defects to inspect for include, but are not limited to, visible cracks, holes, or gaps in the roof sections or between the roof and the tank wall; broken, cracked, or otherwise damaged gaskets; and broken or missing hatches, access covers, caps, or other closure devices. As per 6 NYCRR 373-2.29(i)(2): the owner or operator shall develop and implement a written plan and schedule to perform the inspections and monitoring required. The owner or operator shall incorporate this plan and schedule into the facility inspection plan required under subdivision 373-2.2(g) of this Subpart.

This section serves as a written plan and schedule to perform the required inspections and monitoring detailed in 6 NYCRR 373-2.29(e)(7)(iii)(a). As detailed in 6 NYCRR 373-2.29(e)(7)(iii)(c)(3): the owner or operator shall perform an initial inspection of the air emission control equipment and thereafter, the owner or operator shall perform the inspections at least once every year. Norlite will conduct an annual visual inspection for defects, cracks, holes, gaps, damaged gaskets or other defects which could result in air pollution emissions in conjunction with one of the quarterly Subpart BB inspections conducted by Norlite personnel. The results of the visual inspections will be kept on-site for three years and then stored off-site for the life of the facility.

### 10.3.3 Inspection and Monitoring Requirements

Norlite personnel will inspect the tanks listed in Schedule 1 of Module I of the Part 373 Permit. Specific drawings for these tanks and their associated equipment can be found on engineering drawings NY003-5010, NY003-1312, NY003-1314, NY003-1315, and NY003-1317. While 6 NYCRR 373-2.29(e)(7)(iii)(a) specifies a visual inspection of only the fixed roof and its closure devices, where accessible Norlite will visually inspect the entire outer tank surface plus any closure devices on the tank surface. Any other ancillary equipment attached to the tank is covered under 6 NYCRR 373-2.28 and will not be included in this inspection.

#### 10.3.4 Recordkeeping and Reporting Requirements

As per 6 NYCRR 373-2.29(j)(2), the owner or operator shall record: a. a tank identification number as selected by the owner or operator, b. the date of the inspection was conducted, and c. any defects found. For each defect found during the inspection, the following information will be recorded: the location of the defect, a description of the defect, the date of detection, and corrective action taken to repair the defect. If the repair of the defect is delayed in accordance with the provisions of subdivision 373-2.29(e)(11), the owner or operator shall also record the reason for the delay and the date that completion of repair of the defect is expected.

As per 6 NYCRR 373-2.29(e)(11): the owner or operator shall repair each defect detected during an inspection as follows:

(i) The owner or operator shall make first efforts at repair of the defect no later than 5 calendar days after detection, and repair shall be completed as soon as possible but no later than 45 calendar days after detection.

(ii) Repair of a defect may be delayed beyond 45 calendar days if the owner or operator determines that repair of the defect requires emptying or temporary removal from service of the tank and no alternative tank capacity is available at the site to accept the hazardous waste normally managed in the tank. In this case, the owner or operator shall repair the defect the next time the process or unit that is generating the hazardous waste managed in the tank stops operation. Repair of the defect shall be completed before the process or unit resumes operation.

As per 40 CFR 265.1084(d)(1): the test shall be conducted in accordance with the procedures specified in Method 21 of 40 CFR part 60, appendix A. Each potential leak interface on the cover and associated closure devices shall be checked. Norlite currently conducts Method 21 testing on the agitators of all the tanks listed previously in this document. As per 40 CFR 265.1084(d)(9): for the seals around a rotating shaft that passes through a cover opening, the arithmetic difference between the maximum organic concentration indicated by the instrument and the background level shall be compared with the value of 10,000 ppm. If the difference is less than 10,000 ppm, then the potential leak interface is determined to operate with no detectable organic emissions. Norlite uses a limit of 500 ppm as a determination of leak. Any readings over 500 ppm will trigger maintenance to be conducted on the agitator packing.

Please see Appendix 17 for an example of the form which will be used to conduct and document the annual Subpart CC inspection.

## **11.0 REQUIREMENTS OF OTHER FEDERAL AND STATE LAWS**

This section is presented to demonstrate compliance with 6 NYCRR 373-2.5 entitled, “Manifest System, Recordkeeping and Reporting,” as well as annual generator and hazardous waste reduction reporting requirements, at the Norlite LLC (Norlite).

### **11.1 Manifest Requirements**

As discussed in previous sections of this Operations Plan, the Norlite LLC (Norlite) manages hazardous waste under the following scenarios:

- Receipt of hazardous waste for blending and burning in two rotary kilns to produce lightweight aggregate.
- Receipt of hazardous waste as part of transportation related transfer and temporary storage.

As a result, the manifest requirements applicable to generators of hazardous waste pursuant to 6 NYCRR 372.2(b) are complied with by Norlite LLC for both hazardous waste transported to the Norlite LLC (Norlite) facility, as well as for hazardous waste transported from the Norlite LLC (Norlite) facility for off-site treatment and disposal. In addition, as required by the Land Disposal Restrictions, the required recordkeeping in accordance with 6 NYCRR 376.1(g) is maintained on-file at the facility.

### **11.2 Operating Record**

In accordance with 6 NYCRR 373-2.5(c), the Norlite LLC (Norlite) is required to maintain an operating record at the facility. A description of the items included in the operating record follows:

- Date, type, location and quantity of hazardous waste stored;
- Date, type, location and quantity of hazardous waste generated;

- Records and results of waste analyses;
- Summary reports and details of all incidents requiring implementation of the Norlite LLC (Norlite) Integrated Contingency Plan;
- Records and results of inspections (only required to be maintained for three years);
- Monitoring, testing or analytical data and corrective action where required;
- For off-site facilities, notices to generators as specified in 6 NYCRR 373-2.2(d)(2);
- Manifests (only required to be maintained for three years); and,
- Closure plan and closure cost estimates.

In addition, as required by 6 NYCRR 373-2.5(c)(2)(ix), a certification is submitted to the NYSDEC, no less often than annually, that a program is in place to reduce the volume and toxicity of hazardous waste that is generated to the degree determined by Norlite LLC to be economically practicable. Further, Norlite LLC certifies that the method of storage, treatment and disposal is the most practical method currently available to the Norlite LLC which minimizes the present and future threat to human health and environment. A copy of this certification is maintained in the operating record at the Norlite LLC (Norlite).

### **11.3 Availability, Retention and Disposition of Records**

In accordance with 6 NYCRR 373-2.5(d), the operating record listed in the previous section will be retained until facility closure and will be available for inspection at all reasonable times by a representative of the NYSDEC. The operating record is maintained at the Norlite LLC (Norlite).

### **11.4 Annual Report**

As a generator of hazardous waste within the State of New York, Norlite LLC is required to comply with the annual reporting requirements specified in 6 NYCRR 373-2.5(e). A Hazardous Waste Report is prepared annually by Norlite LLC for the Norlite facility and

submitted to the Commissioner of the NYSDEC by March 1st for the preceding calendar year. Copies of the annual reports are maintained for at least three years at the Norlite LLC (Norlite).

### **11.5 Hazardous Waste Reduction Plans**

Since the Norlite LLC (Norlite) generates greater than 25 tons of hazardous waste per year and has received a Part 373 Permit from the NYSDEC, it was required to develop and submit a Hazardous Waste Reduction Plan (HWRP) in July 1, 1991. In subsequent years, Annual Status Reports and Biennial Updates to the HWRP have been prepared and submitted to the NYSDEC in accordance with the provisions of the Hazardous Waste Reduction Act.

Norlite LLC is strongly committed to reducing the volume of hazardous waste generated at the Norlite facility and will continue to comply with the applicable requirements of the Hazardous Waste Reduction Act including the submittal of Annual Status and Biennial Update reports.

## 12.0 GLOSSARY

<u>Term</u>	<u>Definition</u>
6 NYCRR	Title 6 of the New York Codes, Rules and Regulations
40 CFR	Title 40 of the Code of Federal Regulations
AWFCO	Automatic Waste Feed Cutoff
CAA	Clean Air Act
CERCLA	Comprehensive Environmental Response, Compensation and Liability Act of 1980
CEMS	Continuous Emission Monitoring System
CMS	Continuous Monitoring System
CPT	Comprehensive Performance Test
(US)DOT	(United States) Department of Transportation
DAS	Data Acquisition System
FIA	Federal Insurance Administration
GC	Gas Chromatograph
GPM	Gallons Per Minute
HCl	Hydrogen Chloride
HDPE	High Density Polyethylene
HRA	Hourly Rolling Average
HWM	Hazardous Waste Management (facility)

<b><u>Term</u></b>	<b><u>Definition</u></b>
HWMU	Hazardous Waste Management Unit
HWRP	Hazardous Waste Reduction Plan
LGF	Low Grade Fuel
LLGF	Liquid Low Grade Fuel
MACT	Maximum Achievable Control Technology
MMV	Modified Multivane
MRA	Minute Rolling Average
NACE	National Association of Corrosion Engineers
NFPA	National Fire Prevention Association
NYSDEC	New York State Department of Environmental Conservation
NYSDOH	New York State Department of Health
OSHA	Occupational Safety and Health Administration
P.E.	Professional Engineer
PLC	Programmable Logic Controller
PPE	Personal Protective Equipment
PPMV	Parts Per Million by Volume
PSIG	Pounds per Square Inch Gage
PVC	Polyvinyl Chloride
RCRA	Resource Conservation and Recovery Act
SOP	Standard Operating Procedure
SEQRA	(New York) State Environmental Quality Review Act
TSDF	(hazardous waste) Treatment, Storage or Disposal Facility
USEPA	United States Environmental Protection Agency
VO	Volatile Organic



planning information.

**PREREQUISITE PROCEDURES:**

**REFERENCES:**

**PROCEDURE:**

**1.0 Waste approvals**

**1.1 Initial Waste Characterization (IWC)**

For each new off-site generated waste stream that is proposed to be treated, an initial waste characterization is to identify hazardous characteristics of concern, and define storage and handling requirements for the waste.

The generator must submit a Hazardous Waste/LGF/SLGF specification for all prospective waste streams. The Specification Form provides a means for determining if a waste is subject to the Land Disposal Restrictions of 40 CFR §268, because it requests the generator to identify the applicable RCRA waste codes. The LGF/SLGF specifications form contains a certification that the generator has properly gathered and evaluated the waste stream and that the information submitted to Norlite is true, accurate, complete, and the generator has confirmed that the waste submitted for approval is a representative sample.

Because Norlite has engineered the incinerator feed system to introduce materials that cover a wide spectrum of viscosities, Norlite has the ability to process wastes having a wide range of physical properties. Norlite relies upon its feed planning process (described below) to optimize incinerator feeds that comply with incinerator design specifications and permits.

**2.0 INVENTORY MANAGEMENT**

## 2.1 Receiving

**Bulk Shipments:** Bulk receipts will be tracked by laboratory control numbers. This number follows each shipment from date of receipt through the invoicing process.

**Non-Bulk Containers:**

These containers can include:

Steel Drums (5-85 gallon)

Poly Drum (5-85 gallon)

- a. All drums are sampled in accordance with the Norlite Drum Receiving/Sampling Procedure.
- b. Acceptable drums are issued a unique number that will allow tracking from receipt through disposition of the container received.
- c. The following information may be referenced in the inventory system (not necessarily on the label):
  - (i) Outer container size
  - (ii) Inner container size
  - (iii) Location (drum storage, pumping station, empty)
  - (iv) Date of receipt
  - (v) Waste stream #/ Manifest #
  - (vi) Date processed & drum status (at each stage of handling).
- d. The inventory system has the ability to issue reports with:
  - (i) #/volume of hazardous drums in inventory.
  - (ii) #/volume of non-hazardous drums in inventory
  - (iii) Drum aging
  - (iv) Destination of drums

## 2.2 Containerized Waste Receiving Procedures

Containerized waste generated off-site will be transported by licensed hazardous waste haulers, and will be received in accordance with the procedures described below. Upon receipt, each waste shipment will be

labeled for tracking purposes and the hazardous waste manifest will be reviewed for comparison with the initial waste profile before shipment is sampled. For each waste stream received in a shipment, 100% of the drums of a waste stream will be sampled. The drum samples will be composite for each unique waste stream prior to analysis, with no more than 3 individual drum samples making up one composite sample. The samples will be analyzed as for the parameters described in Table C-01. This data will be used to verify treatability by Norlite.

All samplable wastes received are sampled and composite by waste streams in contained sampling area. All composite samples of miscible liquids, sludges, or solids will be homogenized prior to placement in sample containers. Consistent with 40 CFR 264.71(b)(2), all analyses are not completed prior to signing the manifest and releasing the truck. Discrepancies discovered during later analysis are resolved within 15 days, or are reported as "unreconciled discrepancies" as required under 40 CFR 264.72(b) and as described in section three. If the discrepancy is such that the waste cannot be managed at Norlite; transportation back to the generator or to another treatment facility is arranged.

Upon arrival at Norlite all containerized waste trailer truck must follow these steps:

- a. Truck drivers will report to Gate One and sign in. The gross weight of the load is scaled in.
- b. The shipping papers and the manifest will be inspected and approved by security to ensure that delivery has been made to the proper facility and that the truck has the required permits.

The following information is logged:

- \* Time/date
- \* Generator name and address
- \* Truck driver's name
- \* Truck scale weight

- c. Loaded trucks will then be directed to the unloading area.
- d. Norlite will open the trailer and inspect the trailer's contents. If in order, Norlite will unload the truck's contents. The containers will be unloaded from the truck and organized into rows.

Sufficient aisle space is maintained as required by regulation

- e. As the truck is being unloaded, the containers will also be inspected for damage incurred during transport and for leaks.

Any leaking containers will be placed in appropriate overpack containers. Containers suitable for liquids such as eighty-five gallon poly or steel overpacks will be used. The overpack containers will be labeled to show contents.

- f. LGF Technicians will verify the piece count after unloading.

Any discrepancies in the count will be noted on a copy of the manifest and appropriate action will be taken to reconcile the discrepancy.

- g. Once unloading has begun, all of the containers for Norlite will be unloaded. Typically, trucks will be unloaded on the day that the shipment arrives. However, if for unforeseen circumstances, (such as to reconcile manifest discrepancies, to allow for proper handling and characterization, etc.) it becomes necessary for a truck to remain overnight; the waste containers will be stored in the trailer if they have not been unloaded. The manifest will remain with the transporter, who has custody of the waste.

- h. After the truck is unloaded, an authorization representative of Norlite will sign and date each copy of the manifest to certify that the waste covered by the manifest has been received. A copy of the complete manifest will then be furnished to the driver.

- 1. The guard will logout the truck after verifying that the driver has received a signed copy of the manifest. The truck is weighed out to determine the tare weight.

- j. The LGF technician opens and samples the containers by waste streams for analysis as prescribed by the procedures described in the Waste Analysis Plan. The samples are delivered to the lab and logged on the sample log sheet. The sample log sheet is used to assign an internal lab tracking number (control numbers) for efficiency. The samples are also labeled with the control number. Logged in samples will be analyzed for the parameters outlined in Table C-01 to verify that the waste type specified on the manifest conforms to the previously approved samples waste

type. Incineration parameters (metals, BTU, halogen content) are not performed on samples of waste designated for transshipment to another permitted TSDF. The drums are designated as pumpable liquid for blends, extrudable for direct kiln feed, or transshipment and labeled for inventory tracking.

If any significant discrepancies in waste type are found during the waste fingerprinting analysis, Norlite will follow the procedures outlined in section 3.

k. Pumpable liquid drums are fingerprinted, checked for compatibility, and then bulked into blend tank for analysis. The extrudable drums are analyzed according to the Waste Analysis Plan.

l. The drums are uniquely identified and the location and quantity of hazardous waste received along with the control number cross-references and the date received will be recorded in the operating record of Norlite. The location and quantity received will also be entered into the inventory control room

m. The laboratory will record all results of the waste analysis in the operating record, cross-referencing and to New York DEC.

n. Within two business days after acceptance, copies of the manifest will be sent to the generator and to New York DEC.

o. A copy of each manifest will be retained at Norlite for at least three years from the date of delivery.

### **3.0 RESOLUTIONS OF MANIFEST DISCREPANCIES**

#### **3.1 Resolution of manifest discrepancies**

Any significant discrepancies as defined by 40 CFR 264.72 and NYCRR 372.4(b) will be handled according to the following procedures:

a. Any significant discrepancies in piece count or waste type found during the receiving process will be noted on the manifest.

b. When significant discrepancies are found, Norlite management will attempt to reconcile the discrepancy with the generator and/or transporter by telephone, facsimile or written correspondence. Resolution will be accomplished by examining

all records of quantities and waste type associated with the disputed shipment.

- c. If a discrepancy in waste type is such that the waste can still be treated by the facility, Norlite will accept the shipment, and steps will be taken to reconcile the difference as described above.

Acceptable waste type discrepancies would include differences in physical properties (e.g., heat of combustion, specific gravity, physical state) that, although different from those measured in the characterization analysis, still fall within the range of physical properties that Norlite is capable of treating.

- d. If the discrepancy cannot be resolved within 15 days, a letter will be submitted by Norlite to the EPA Regional Administrator and the New York DEC Director describing the discrepancy, the attempt to reconcile it, and a copy of the disputed manifest.

- e. Records of all attempts to reconcile discrepancies will be kept in Norlite's Operating Record.

- f. If Norlite discovers any significant discrepancies in waste type during the waste receiving analysis that indicates the waste is of a type which cannot be treated by Norlite, Norlite will either reject the waste back to the generator or ship the waste to another facility permitted to manage the waste. Examples of non-acceptable discrepancies would include un-permitted waste codes, TSCA-regulated levels of PCB's, pathological or etiological materials, radioactive components, or explosive materials under the conditions of incineration.

#### **4.0 Review and use of land disposal restrictions (LDR) notification forms and LDR certifications**

In addition to manifests, bills of lading, and other paperwork required for the transportation of hazardous waste, each shipment of restricted hazardous waste must be accompanied by an LDR notification.

The LDR notification must include the manifest number associated with the waste being shipped, the EPA waste code(s), and waste analysis data where available.

In specifying the applicable treatment standard, the wastewater or non--wastewater category and treatment subcategory (where applicable) for all waste codes must be specified.

Once a waste shipment has passed through Gate one and has parked within a contained sampling station or unloading station for waste collection, a review of the LDR notification will be performed. The review will include:

- a. A comparison of the manifest number on the LDR form with the accompanying manifest.
- b. A comparison of the restricted waste codes specified in the manifest with the restricted waste codes listed in the LDR notification.
- c. A determination as to whether treatment subcategories have been specified.

If discrepancies or deficiencies are noted during the LDR notification review, the generator will be contacted to resolve the discrepancy or correct the deficiency. Any discrepancies or deficiencies will be noted on the LDR notification form and the waste will be accepted for treatment.

## **5.0 Processing**

### **5.1 Compatibility**

Samples of composited waste streams for pumpable liquid drums will be tested with material in a targeted storage tank to assure compatibility according to Norlite SOP#4-005. No more than 3 drum samples of a given waste stream will make up 1 composite sample. Norlite will maintain representative samples for the contents of each LGF storage tank. Compatibility testing will be performed by placing an aliquot of the waste sample into the appropriate tank sample. The volume of waste sample used is proportional to the amount of waste being added to the tank in relation to the existing volume of the tank. Acceptable compatibility test results will be determined in a similar fashion as that used for determining compatibility of bulk waste

receipts.

## 5.2 Unloading

The waste drums designated for a blend will be staged in the drum processing building according to their analysis and approved compatibility. The drums are pumped into the storage tank using the pumps on the off-loading pad or a drum pump depending on material consistency and pump availability.

WAP 2 analysis will be conducted on the final drum liquid blend or drum- bulk liquid blend prior to incineration to ensure feed rate compliance. The sample will be analyzed as for the parameters described in Table C-01.

Unique "ID" numbers or batch numbers shall be used to identify groups of drums for blending (as compatibilities are completed) or SLGF feed as is needed to comply with permit and operational needs.

As each drum is removed from the waste inventory, its inventory number will be entered into the data base to ensure proper waste tracking. The drum will then be pumped into the desire tank.

## 5.3 Analysis

After all the drums have been pumped into the storage tank, the tank permitted is agitated or circulated for a minimum of one hour. At the end of this period, the tank may be sampled for a complete analysis per the Waste Analysis Plan parameters.

## 5.4 Processing

Wastes in the LGF tanks may be processed in one of two ways depending on the final analysis:

- a. Directly fed to the kiln if all the parameters are certifiable

according to the Waste Analysis Plan.

- b. Blending into another tank if one or more of the parameters are not within our feed limit.

NORLITE LLC  
STANDARD OPERATING PROCEDURE  
TRANSFER STATION SCENARIOS  
PRACTICED AT NORLITE

SOP# 6-001

The following are the transfer station scenarios practiced by Norlite LLC. These transfer station activities involve the receipt and direct transshipment of wastes to other permitted TSD Facilities, with no incineration activities at Norlite. These activities take place in the same Part 373 permitted storage and handling areas as for wastes treated on site. All transfer of containers or waste between vehicles takes place only at the truck unloading areas shown in Drawings Nos. NY-D\_C-3008 and 2475-50, all transportation-related temporary storage scenarios below are manifested from the point of generation, or previous TSD, to another off-site TSD.

Transfer A

A transporter picks up non-hazardous waste from a generator and manifests it to a TSD other than Norlite. The truck is a tractor/trailer rig. The truck goes to Norlite where the driver unhooks the trailer and leaves it in the truck staging containment area shown in Drawing #NY003-D3202. The manifest remains with the trailer. Another driver comes with another truck and picks up the trailer to deliver it to the TSD Facility listed on the manifest. The trailer can be staged at Norlite for a maximum of 48 hours.

Transfer B

Same as Transfer A except that the material is hazardous waste.

Transfer C

Drummed wastes (hazardous and non-hazardous) are transferred truck-to-truck enroute to another permitted TSD Facility. The manifest(s) are made out from the generator to the designated TSD Facility. Norlite's truck unloading containment area serves as a place to make a drum transfer from a straight box van to a tractor/box trailer rig.

### Transfer D

Same as Transfer C except the drums are temporarily (24-48 hours) staged in the Norlite permitted drum storage areas before being loaded onto the tractor/box trailer. The manifests are made out to the other permitted TSD Facility.

### Transfer E

Drummed wastes (hazardous and non-hazardous) are manifested to Norlite where they are accepted using the normal operating procedures. The drums are stored in the Norlite permitted drum storage area. Instead of processing these drums, Norlite generates a new manifest and ships the drums to another permitted TSD Facility.

For all of the scenarios above, the hazardous waste must meet Norlite's waste acceptance criteria, as described in the Waste Analysis Plan. Protocols described in SOP# 4-010 and #4-011 and of the Waste Analysis Plan must be followed in executing the above transfer station scenarios. Only hazardous waste authorized by the Part 373 Permit will be accepted for all scenarios of transfer operations, and the permitted storage capacity of the drum storage areas will not be exceeded.

## DUDICK PROTECTO LINE 900 VINYL ESTER LINING/TOPPING

### Selection Data

**General:** Protecto-Line 900 system is a thermosetting vinyl ester resin. Provides high protection against concentrations of organic acids, inorganic acids and solvents. It exhibits superior resistance to alkali and solvent concentration because the vinyl ester epoxy has no hydrolyzable ester groups. The few ester groups which are present are formed at the molecular terminals where stability is provided by steric hinderance from the methyl group of the methacrylic acid. A silica filled basccoat and topcoat and 9.8 oz. woven fiberglass roving reinforcement from a tough, corrosive resistant system for concrete and steel exposed to general chemical environments.

<b>Property:</b>	Tensile Strength	2,400 PSI
	Flexural Strength	8,600 PSI
	Compressive Strength	12,500 PSI
	Hardness (Barcol)	70-75
	Coefficient of Expansion (n X 10 <sup>-5</sup> in./in./°f)	12-15

**Chemical Resistance:** Organic Acids Inorganic Acids Salts Oils Alkali Solutions  
Protecto-Line 800/900 systems are highly resistant to a wide range of caustic and acids, chemicals, salts and oils.

**Specifications:** Lining shall be a 1/8" thick silica filled vinyl ester based resin, consisting of a deep penetrating primer, a 1/16" basecoat, 9.8 oz. woven fiberglass roving and a 1/16" topcoat as manufactured by Dudick Corrosion-Proof, Inc. Materials shall be applied in accordance with manufacture's recommended practices.

**Protoco-Line System:** The Protecto-Line system uses several layers of thermosetting, filled vinyl ester resins to build-up the protection that vulnerable steel and concrete need in chemically oriented manufacturing or processing operations. When fully cured, the separate elements lose their individual identity and become a single, monolithic topping.

Each of the five elements in the system not only provides its own special function, but also supports the other elements.

**Primer:** Protecto-Line Primer 27 is designed to prevent sand-blasted steel from developing rust bloom prior to the application of a Protoco-Line system, Concrete must always be primed to aid in the "wetting out" required for good bonding.

**Basecoat:** Protecto-Line 800/900 vinyl ester resins are filled with silica or carbon, depending on the chemical environment involved. The filler reduces the coefficient of expansion and provides a thixotropic base on which to embed the fiberglass or synthetic roving.

**DUDICK PROTECTO LINE 900  
VINYL ESTER LINING/TOPPING  
Continued**

**Reinforcement:** A woven fiberglass or synthetic fabric is used to help bridge small surface cracks and provide additional strength to resist thermal shock. It is applied to the wet basecoat and becomes an integral part of it, acting much the same as reinforcing bar does in concrete.

**Saturant:** Protecto-Line vinyl ester resins is used to wet out the reinforcing fabric, thus providing a mechanical and chemical bond.

**Topcoat:** Protecto-Line silica or carbon filled vinyl ester resins provide an abrasion resistant and chemical resistant outer barrier. Inert aluminum oxide fillers can be added to this coat to significantly increase skid and abrasion resistance/


## Sikaflex - 1a Elastic Sealant/Adhesive

### Technical Data

- DESCRIPTION:** Sikaflex - 1a is a premium-grade, high -performance, moisture-cured, 1-component, polyurethane-base, non-sag elastomeric sealant.
- WHERE TO USE:** Designed for all types of joints with maximum depth of 1/2 in. Excellent for small joints and fillets... windows, door frames, reglets, flashing, glazing, and many construction adhesive applications. Suitable for vertical and horizontal joints; readily placeable at 40F. Has many applications as an elastic adhesive between materials with dissimilar coefficients of expansion.
- ADVANTAGES:**
- \* Easy, low-cost, ready-to-use
  - \* Eliminates time, effort, and equipment for mixing, filling cartridges, pre-heating or thawing, and cleaning of equipment
  - \* High elasticity - Cures to a tough, durable, flexible consistency with exceptional cut- and tear- resistance
  - \* Excellent adhesion - Bonds to most construction materials...without primer in most cases
  - \* Long life
  - \* Excellent resistance to aging, weathering
  - \* Proven in tough climates around the world
  - \* USDA- and FDA- approved ☼
  - \* Approved for use in contact with potable water
  - \* Resists fuel, mineral oils, and dilute minerals, plant and animal fats
  - \* Odorless, non-staining. Can be painted over with water-, oil-and rubber-base paints. Since some paints, dry slowly and the surface may remain slightly tacky, a preliminary test is essential.
  - \* Meets Fed Spec TT-S-00230C, Type II Class A
  - \* Meets EPA regulations on water extractability
  - \* Meets Canadian Standard 19-GP-16A, Type II

---

☼ Chemically acceptable to the U.S. Department of Agriculture for use in meat and poultry processing area under federal inspection. Meets FDA Regulation Title 21 on indirect Food Additives, as found in Part 174; Part 175, Paragraph 175.105; Part 177, Paragraph 177.1680, and Paragraph 177.2600, being composed of ingredients acceptable and transporting food.




TANK PLAN

SCALE: 1/4" = 1'-0"

NOTES:

1. MEASUREMENTS OBTAINED AT THE BOTTOM OF THE TANK WERE MADE BY REMOVING SMALL SECTIONS OF GLASS AND READING SHELL MET. THICKNESS.
2. MEASUREMENTS OBTAINED AT THE UNDERSIDE OF NOZZLE (B) WERE MADE ON EXISTING EXPOSED MET.



EXISTING UNDER GROUND STORAGE TANK

TANK #335-300

TANK ELEVATION

0	ISSUED	9/21
NO.	DESCRIPTION	DA
PROJECT:	AGITATOR INSTALLATION	
CLIENT:	NORLITE CORP.	
FILE:	TANK #335-300 &	ST
DWG /	WA-94152	CA
SHEET 1 OF 1	DATE 09/21/00	NO.
W. G. S. J.		12



## COMPATIBILITY CHART FOR FLUIDS, SEALS AND METALS

FLUID	METAL					SEAL MATERIAL					FLUID	METAL					SEAL MATERIAL				
	ALUMINUM	BRONZE	IRON	STEEL	ST. STEEL	BUNA	BUTYL	NEOPRENE	TEFLON	VITON		ALUMINUM	BRONZE	IRON	STEEL	ST. STEEL	BUNA	BUTYL	NEOPRENE	TEFLON	VITON
Lard - Lard Oil	G	G	G	G	G	G	F	G	G	G	Rapeseed Oil	G	G	G	G	G			G	G	
Linseed Oil	G	G	G	G	G	G	G	G	G	G											
Lube Oil	G	G	G	G	G	G	F	G	G	G	Sewage	G	G	G	G	G	F	F	G	G	
Methyl Alcohol - Methanol	G	G	G	G	G	G	G	G	G	G	Skyrol	G	G	G	G	G					
Methyl Amyl Alcohol	G	G				G	F	F	G	G	Sodium Bicarbonate	G	G	F	F	G	G	G	G	G	
Methyl Amyl Acetate	G	G				G	P	P	G	G	Sodium Bisulphate	F	F	P	P	G	G	G	G	G	
Methyl Acetate	G	G	G	G	G	P		P	G	G	Sodium Carbonate	F	F	G	G	G	G	G	G	G	
Methyl Chloride	P	P	P	P	G	F	F	P	G	G	Sodium Chloride	F	F	G	G	G	G	G	G	G	
Methyl Ether	G	G				G	F	P	G	G	Sodium Cyanide	P	P	G	G	G	G	G	G	G	
Methyl Ethyl Ketone	G	G	G	G	G	P	F	P	G	P	Sodium Hydroxide	P	P	G	G	G	F	F	F	G	
Methyl Isobutyl Ketone	G	G	G	G	G	P	F	P	G	P	Sodium Hypochlorite	P	P	P	P	G	F	F	F	G	
Methyl Propyl Ketone	G	G	G	G	G	P		P	G	P	Sodium Metaphosphate	F	F	P	P	G	G	G	F	G	
Methylene Chloride	F	G	G	G	G	P		P	G	P	Sodium Nitrate	G	F	G	G	G	G	G	F	G	
Milk	G	P	P	P	G	G	G	G	G	G	Sodium Perborate	G	F	F	G	G	G	G	G	G	
Mineral Oils	G	G	G	G	G	F	F	G	G	G	Sodium Peroxide	G	F	F	F	G	F	G	F	G	
Morasses	G	G	G	G	G	G		G	G	G	Sodium Phosphate, Mono-Basic	G	F	F	F	G	G	G	G	G	
											Sodium Phosphate, Di-Basic	F	F	F	F	G	G	G	G	G	
											Sodium Phosphate, Tri-Basic	P	P	G	G	G	G	G	G	G	
Nadina	G	G	G	G	G	P	P	P	G	G	Sodium Silicate	P	F	G	G	G	G	G	G	G	
Naphthalene	G	G	G	G	G	P	P	P	G	G	Sodium Sulphate	G	G	G	G	G	G	G	G	G	
Nadina Solvents	G	G	G	G	G	P	P	P	G	G	Sodium Sulphide	P	P	G	G	G	G	G	G	G	
Natural Gas	G	G	G	G	G	P	P	P	G	G	Sodium Thiosulphate	G	F	F	F	G	G	G	G	G	
Nitric Acid - (Conc)	F	F	P	P	G	P	P	P	G	G	Soya Bean Oil	G	G	F	F	G	G	G	G	G	
Nitric Acid, Crude	F	F	P	P	G	P	P	P	G	G	Stoddard Solvent	G	G	G	G	G	P	F	F	G	
Nitric Acid, Diluted	F	F	P	P	G	P	P	P	G	G	Styrene	G	G	G	G	P	P	P	P	G	
Nitrobenzene	G	G	G	G	G	P	P	P	G	G	Sugar	G	G			G	G	G	G	G	
Nitroethane	G	G	G	G	G	P	P	P	G	G	Sulphur, Dry	G	P	G	G	G	F	F	F	G	
Nitromethane	G	G	G	G	G	P	P	P	G	G	Sulphur, Chloride	P	P	F	F	F	F	P	F	G	
Nitropropane	G	G	G	G	G	P	P	P	G	G	Sulphuric Acid - 10% Cold	P	P	P	P	G	G	G	G	G	
Nitrogen Peroxides	G		G	G	G	G		G	G	G	Sulphuric Acid - 10% Hot	P	P	P	P	F	G	G	G	G	
											Sulphuric Acid - 10-75% Cold	P	P	P	P	F	F	G	F	G	
											Sulphuric Acid - 10-75% Hot	P	P	P	P	F	F	G	F	G	
											Sulphuric Acid - 75-95% Cold	P	P	G	G	G	F	F	F	G	
											Sulphuric Acid Fuming	P	P	G	G	F	P	P	P	G	
											Sulphuric Acid Fuming Hot	P	P	G	G	F	P	P	P	G	
											Synthetic Lubricants	G				G	F	P	F	G	
Oil Oil	G	G	F	F	G			G	G		Tar	G	G	G	G	G	G	P	G	G	
Peanut Oil	G	G	F	F	G			G	G		Tetraethyl Lead	G	G	G	G	G	G	P	G	G	
Perthane	G	G	G	G	G	G	G	G	G	G	Toluene - Toluol	G	G	G	G	G	G	P	G	G	
Perchloroethylene	G	G	G	G	G			G	G		Trichloroethylene	G	G	G	G	G	P	P	P	G	
Perchloroethylene Ether	G	G	G	G	G	F	P	F	G	G	Tung Oil	G	G	F	F	G	G	G	G	G	
Perchloroethylene Naphtha	G	G	G	G	G	P	P	P	G	G	Turbine Oil					G	G	G	G	G	
Perchloroethylene Oils	G	G	G	G	G	P	P	P	G	G	Turpentine	G	F	F	F	G	G	P	F	G	
Perchloroethylene Solvents	G	G	G	G	G	P	P	P	G	G											
Pheno	G	F	F	F	G	P	P	P	G	G	Varnish	G	G	F	F	G	G	P	G	G	
Phosphoric Acid, Crude	P	P	F	F	G	F	G	F	G		Versol	G	G	G	G	G					
Phosphoric Acid, Pure 85%	P	P	P	P	G	F	G	F	G		Vegetable Oils	G	G	G	G	G	G	G	G	G	
Pin Oil	G	G				G	F	P	F	G											
Potassium Hydroxide	P	P	F	F	G	F	G	F	G	G	Water, Fresh	G	F	G	G	G	G	G	G	G	
Propylene	G	G	G	G	G	P	P	P	G	G	Water, Sea	F	F	F	F	G					
Propylene	G	G	G	G	G	P	P	P	G	G											
Propionic Acid	G	L	P	P	G	F	F	F	G	G	Xylene - Xylol	G	G	G	G	G	P	P	P	G	
Propyl Sulphuric Propanol	G	G	G	G	G	G	G	G	G	G											
Propylene Glycol	G	G	G	G	G	G	G	G	G	G											
Propylene Oxide	G	G	G	G	G																

SLC Consultants/Constructors, Inc.

---

July 23, 1985

Norlite Corp.  
628 S. Saratoga Street  
Cohoes, NY 12047

ATTENTION: K.D. Hedges

Dear Mr. Hedges:

The Poly-America 40 mil High Density Polyethylene installed for your "low grade fuel" system was installed following the manufacturers installation procedures. Also, seam testing was performed in accordance with the American Society for Testing and Materials Standard D4437-84. All flat seams were vacuum checked.

If I can be of any further assistance, please let me know.

Sincerely,



Donald J. Kuhn  
President  
SLC CONSULTANTS/CONSTRUCTORS, INC.

DJK/rs

SLC Consultants/Constructors, Inc.

September 23, 1985

Norlite Corp.  
628 So. Saratoga Street  
Cohoe, NY 12047

ATTENTION: Mr. Hedges


Dear Mr. Hedges:

In response to your inquiry I am presenting the following information:

1. The personnel that have been working at your site were either Kenneth W. Kuhn or Wayne S. Less. Mr. Kuhn has been installing synthetic liners since 1978 and Mr. Less since 1980. Some of the projects are depicted on the enclosed sheets. Both men have millions of square feet of installation experience. Both are college graduates with extensive construction experience.
2. The flat welds were performed using a Leister Automatic Hot Air Welding machine, X-10. A picture is attached. Please note that there is no operating manual available from the manufacturer. This is very unusual but true. The Leister X-10 is the same machine that was used to seal the High Density Polyethylene liner at the Love Canal in 1984. In fact, one of our machines was rented to the contractor.
3. Any repairs or penetrations were done with a Wegener "WEG12M" extrusion welder. The operating manual is attached.
4. Seam testing was performed by using a vacuum box in accordance with ASTM D4437-84, copy attached.
5. The liner used was supplied by Poly-America, Inc. A brochure is attached. Please note on the second page the picture of the Leister X-10 welder. The thickness of the sheet supplied was 40 mil.


If any more details are required, please contact me.

Sincerely,



Donald J. Kuhn  
President  
SLC CONSULTANTS/CONSTRUCTORS, INC.

## PIPE PENETRATION DETAILS



A prefabricated boot is slipped over penetration pipe. The base sheet is welded to the HDPE liner with a Wegener Fusion Welding Gun. The boot is strapped to pipe with a butyl seal and 3/4" stainless steel band.

All work done by experienced liner installation workers under close supervision.

Norlite Corp.  
628 S. Saratoga St.

## MINIMUM SHELL THICKNESS (FROM ASME SECTION VIII)

For 15 psig internal pressure

Shall circumferential stress, UG-27(c)(1)

Allowable stress value  
 $S = 15,000 \text{ psi}$

Joint Efficiency  
 $E = 0.60$  (table UW-12 for Type No. (3) butt joint)

$$t = \frac{PR}{SE - 0.6P}$$

$$t = \frac{15 (116.6875)}{15,000 (0.6) - 0.6 (15)} = 0.195 \text{ in}$$

Measured Shell Thickness

<u>Tank No.</u>	<u>Thickness in Inches</u>
335-300	0.394
335-400	0.381
335-500	0.387
335-600	0.384

Estimated Service Life

Estimated corrosion rate = 0.011 inches/year

Estimated service life =  $\frac{\text{Measured thickness} - \text{Minimum thickness}}{\text{Corrosion rate}}$

<u>Tank No.</u>	<u>Estimated Service Life in Years</u>
335-300	18.1
335-400	16.9
335-500	17.5
335-600	17.2

# Carboline

## CARBOMASTIC<sup>®</sup> 15

350 HANLEY INDUSTRIAL COURT • ST. LOUIS, MO. 63144 • 314-644-1000

Appendix 9 - Operations Plan

### SELECTION DATA

**GENERIC TYPE:** High build, modified aluminum epoxy mastic. Part A and Part B mixed prior to application.

**GENERAL PROPERTIES:** Self priming, high build coating with excellent adhesion to rusted steel and most aged paints. Over ten years proven field performance in corrosive environments. Consult Carboline for case history information. Only a single coat required for most applications. Hand or power tool cleaning is acceptable surface preparation for most surfaces. For severely corroded surfaces, see surface preparation instructions for non-immersion service on back page.

**RECOMMENDED USES:** Particularly recommended for re-painting rusty steel and for upgrading old, deteriorated coatings. Also used where hand cleaned steel is being coated for the first time. Ideal for metal buildings, fences, piping, process equipment, highway bridges and exposed structural steel.

**NOT RECOMMENDED FOR:** Immersion service in acids, alkalis or solvents.

#### CHEMICAL RESISTANCE GUIDE:

Exposure	Immersion	Splash and Spillage	Fumes
Acids	NR	Fair	Very good
Alkalies	NR	Good	Excellent
Solvents	NR	Good	Excellent
Salt Water	Excellent*	Excellent	Excellent
Water	Excellent*	Excellent	Excellent

\*Discolors to gray.

**TEMPERATURE RESISTANCE:** (non-immersion)

Continuous: 180°F (82°C)  
Non-continuous: 250°F (121°C)

**FLEXIBILITY:** Excellent      **WEATHERING:** Excellent

**ABRASION RESISTANCE:** Fair

**SUBSTRATES:** Rusty steel, aged galvanized steel, or others as recommended.

**TOPCOAT REQUIRED:** Normally none, but can be top-coated with most generic types. Some alkyd or oil modified paints exhibit poor adhesion. Consult Carboline Technical Service for specific recommendations.

**COMPATIBILITY WITH OTHER COATINGS:** May be used over most generic types of coatings which are tightly

adhering and properly prepared; inorganic and organic zinc primers. A test patch is recommended for use over existing coatings.

### SPECIFICATION DATA

**THEORETICAL SOLIDS CONTENT OF MIXED MATERIAL:**

By Volume

Carbomastic 15

90% ± 2%

**RECOMMENDED DRY FILM THICKNESS PER COAT:** (Measured in addition to the rust or steel substrate) 5 mils (125 microns) minimum. For severe exposures 7 mils (175 microns) minimum is recommended.

**THEORETICAL COVERAGE PER MIXED GALLON\*:**  
1444 mil sq. ft. (36.0 sq. m/l @ 25 microns)  
289 sq. ft. at 5 mils (7.2 sq. m/l @ 125 microns)

\*NOTE: Material losses during mixing and application will vary and must be taken into consideration when estimating job requirements.

**SHELF LIFE:** 24 months minimum.

**COLORS:** Aluminum only. May bronze under certain application and curing conditions. Aluminum color will return upon weathering. In order to obtain a highly reflective, uniform appearance, a topcoat of Carboline 1265 may be applied.

**GLOSS:** Not applicable.

### ORDERING INFORMATION

Prices may be obtained from Carboline Sales Representative or Main Office. Terms - Net 30 days.

**SHIPPING WEIGHT:**

	2's	10's
Carbomastic 15	25 lbs. (11.4 kg)	119 lbs. (54.1 kg)
Carbomastic Thinner	8 lbs. in 1's (3.6 kg)	40 lbs. in 5's (18.2 kg)

**FLASH POINT:** (Pensky-Martens Closed Cup)

Carbomastic 15 Part A: 200°F (93°C)  
Carbomastic 15 Part B: 94°F (34°C)  
Carbomastic Thinner: 73°F (23°C)

# APPLICATION INSTRUCTIONS

These instructions are not intended to show product recommendations for specific service. They are issued as an aid in determining correct surface preparation, mixing instructions, and application procedure. It is assumed that the proper product recommendations have been made. These instructions should be followed closely to obtain the maximum service from the materials.

**SURFACE PREPARATION:** Remove any oil or grease from surface to be coated with clean rags soaked in Carboline Thinner #2 or toluol.

**Steel:** For water immersion service, dry abrasive blast to a Near White Metal Finish in accordance with SSPC-SP 10 to a degree of cleanliness in accordance with NACE #2 to obtain a 1-3 mil (25-75 micron) blast profile.

For non-immersion service, clean per Power Tool or Hand Tool in accordance with SSPC-SP 3 or SSPC-SP 2, respectively, to a cleanliness defined by SSPC-St 2 pictorial standards. Alternatively, for more severe environments, dry abrasive blast per SSPC-SP 7 (brush-off blast) to a degree of cleanliness defined by SSPC-Sa 1 pictorial standards. Water blasting is an acceptable means of preparing the surface to a cleanliness defined by SSPC-St 2.

**MIXING:** Mix separately, then combine and mix in the following proportions:

	<u>2-Gal. Kit</u>	<u>10-Gal. Kit</u>
Carbomastic 15 Part A	1 Gal.	5 Gals.
Carbomastic 15 Part B	1 Gal.	5 Gals.

Thin up to 25% by volume with Carbomastic Thinner.

**POT LIFE:** Four hours at 75°F (24°C) when thinned 25%, two hours at 75°F unthinned and one hour at 90°F (32°C) unthinned. Pot life ends when the coating becomes too viscous to use.

## APPLICATION TEMPERATURES:

	<u>Material</u>	<u>Surfaces</u>
Normal	65-85°F (18-29°C)	65-85°F (18-29°C)
Minimum	50°F (10°C)	40°F (4°C)
Maximum	90°F (32°C)	130°F (54°C)

	<u>Ambient</u>	<u>Humidity</u>
Normal	65-85°F (18-29°C)	35-80%
Minimum	40°F (4°C)	0%
Maximum	100°F (38°C)	95%

Do not apply when the surface temperature is less than 5°F (12°C) above the dew point.

Special thinning and application techniques may be required above or below normal conditions.

**SPRAY:** Use adequate air volume for correct operation.

Use a 50% overlap with each pass of the gun. On irregular surfaces, coat the edges first, making an extra pass later.

**NOTE:** The following equipment has been found suitable, however, equivalent equipment may be substituted.

**Conventional:** Use 1/2" minimum I.D. material hose. Hold gun 8-10 inches from the surface and at a right angle to the surface.

<u>Mfr. &amp; Gun</u>	<u>Fluid Tip</u>	<u>Air Cap</u>
Binks #18 or #62	67	67B
DeVilbiss P-MBC or JGA	D	64
Approx. .086" I.D.		

**Airless:** Use 3/8" minimum I.D. material hose. Hold gun 12-14 inches from the surface and at a right angle to the surface.

<u>Mfr. &amp; Gun</u>	<u>Pump*</u>
DeVilbiss JGB-507	QFA-514
Graco 205-591	President 30:1 or Bulldog 30:1
Binks Model 500	Mercury

\*Teflon packings are recommended and available from pump manufacturer.

Use a .023 to .027" tip with 2400 psi.

**BRUSH OR ROLLER:** Use clean, short, natural bristled brush or medium nap roller. Work coating into all irregularities. Brush or roller application may result in a non-uniform bronze color.

## DRYING TIMES:

Between coats:	6 days at 40°F (4°C)
	3 days at 60°F (16°C)
	24 hours at 75°F (24°C)
	18 hours at 90°F (32°C)
Final cure:	20 days at 40°F (4°C)
	10 days at 60°F (16°C)
	5 days at 75°F (24°C)
	3 days at 90°F (32°C)

**CLEANUP:** Use Carboline Thinner #2 or xylol.

## STORAGE CONDITIONS:

Temperature: 45-110°F (7-43°C) Humidity: 0-100%

**SPECIFICATION STANDARD  
GALVANIC ANODE CATHODIC PROTECTION SYSTEM  
ENGINEERING, MATERIALS AND INSTALLATION**

**1.0 GENERAL**

Work under this section is subject to all the requirements of the Contract Documents, including the General Conditions, and Special Conditions of the Specifications.

**2.0 SCOPE OF WORK**

2.1 It is the intent under the conditions of this Contract that the Contractor under this section, provide the services of a NACE Corrosion Specialist for the purpose hereinafter specified. As such, said Specialist shall be considered the Contractor's Agent.

2.2 All fees and/or other charges for services rendered by the Contractor's corrosion engineering Specialist and/or firm shall be included completely and totally under this Contract.

2.3 The cathodic protection system work shall include the furnishing and installation of all electrical work, wiring, conduits, fittings, anodes, bonding, thermite brazing, holiday detection, and all other work and items required for a complete and functioning cathodic protection system with a minimum design life of 20 years. .

2.4 Cathodic protection using galvanic anodes shall be provided for underground metallic structures as follows:

2.5 The cathodic protection system shown on the drawings shall be confirmed as adequate for the soil and tank conditions by the corrosion engineering specialist.

**3.0 REFERENCE STANDARDS**

3.1 The cathodic protection installation shall comply with applicable requirements codes, laws and ordinances of Federal, State, and local bodies having jurisdiction; the requirements of the local power company; the electrical requirements and/or codes of insurance underwriters; the Standards of the

National Electrical Manufactures Association (NEMA); Underwriters' Laboratories (UL); the Institute of Electrical and Electronics Engineers (IEEE); the National Association of Corrosion Engineers (NACE), including applicable supplements, bulletins, and special rulings.

3.2 Where more stringent requirements than code are shown or specified, the more stringent requirements shall apply. All electrical items shall be UL listed or labeled, where such listing or labeling is obtainable.

4.0 **RELATED WORK SPECIFIED ELSEWHERE**

4.1 Dielectric couplings, protective pipe coating, wrapping, and patching will be provided by the Contractor.

4.2 Backfilling other than specified herein for anodes will be provided by the Contractor.

5.0 **STANDARD PRODUCTS**

Materials and equipment submitted for approval under this specification shall be a product of a manufacturer regularly engaged in the manufacture of the product, shall be the respective manufacturer's standard design and shall meet the requirements of the specifications.

6.0 **MATERIALS AND EQUIPMENT**

6.1 **ANODE**

6.1.1 The dimensions of magnesium anodes shall be the standard anode sizes for the weights specified. Magnesium anodes shall be Dow Galvomag and shall conform to the following specifications:

Aluminum (Al).....	0.10% maximum
Manganese (mn).....	0.50% to 1.30%
Zinc (Zn).....	0.00
Silicon (Si).....	0.00
Copper (Cu).....	0.02% maximum
Nickel (Ni).....	0.001% maximum
Iron (Fe).....	0.03% maximum
Other Impurities - each.....	0.05% maximum
- total.....	0.03% maximum
Magnesium (Mg).....	Balance

All anodes shall come prepackaged in special backfill material consisting of 75% ground hydrated gypsum, 20% powdered bentonite and 5% anhydrous sodium sulfate. The backfill shall have a grain size such that 100% is capable of passing through a 20 mesh screen and 50% will be retained by a 100 mesh screen. The backfill mixture shall be firmly packaged around the magnesium anode within a cotton bag by means of adequate vibration.

For standard cast ingots, the magnesium anode weight of backfill required, shall be as follows:

<u>Magnesium Anode ( in pounds)</u>	<u>Backfill (in pounds)</u>	<u>Total Weight (per Anode)</u>
3	6	9
5	9	14
9	15	24
17	25	42
20	50	70
32	38	70
48	48	96

6.1.3 Anode lead wires shall be No. 12 AWG solid copper conductors with TW insulation. Lead wires shall be a minimum of ten feet in length.

6.1.4 Standard sized magnesium anodes shall be cast with a perforated, galvanized steel core, with the weight of the core not to exceed 0.10 pounds per linear foot. One end of the anode shall be recessed to expose the core for the lead wire connection. The lead wire shall be silver soldered to the core and the connection fully insulated by filling the recess with an electrical potting compound.

## 6.2 CONDUCTORS

6.2.1 All conductors shall be copper.

6.2.2 No. 12 AWG wire shall have TW insulation which complies with Federal Specification J-C-30. The contractor shall have the option of substituting polyethylene insulation for TW.

6.2.3 No. 8 AWG wire or larger shall be cathodic protection cable specifically designed for the purpose, shall comply with ASTM D 1248 and shall be insulated with high molecular weight polyethylene, type I, class C, grade 5.

6.2.4 The minimum thickness of insulation at any point shall not be less than 90 per cent of the nominal wall thickness. The wall thickness for AWG size No. 8 through No. 2 shall be 7/64" and for sizes No. 1 through No. 4/0, 8/64".

### 6.3 TEST STATIONS

Test Stations shall be of the flush mounted type with cast iron covers. Handley PT4R5L or approved equal are acceptable.

### 6.4 PERMANENT REFERENCE CELLS

Permanent reference cells shall be direct burial copper/copper sulfate electrodes for underground use, prepackaged in special backfill material and have a minimum design life of 15 years.

### 6.5 THERMITE BRAZING

Thermite brazing of electrical connections shall be Erico "Cadweld", or approved equal.

### 6.6 COATING

Coating compound shall be cold applied coal-tar base mastic or approved pipe line coating such as Royston A-51.

### 6.7 FLANGE INSULATION

Flange insulation shall consist of full faced, neoprene faced phenolic gaskets with full length Mylar sleeves and double, phenolic washers as manufactured by PSI or approved equal. High temperature kits shall be used if temperatures exceed 200°F

### 6.8 CASING SEALS

Hard rubber casings seals shall be used where the pipe passes through concrete walls. These shall be as manufactured by Thunderline Corporation or approved equal.

### 7.0 SUBMITTALS

### 7.1 SHOP DRAWINGS

7.1.1 As soon as practicable and within thirty (30) days after the date of receipt of notice to proceed, and before any material or equipment is purchased, the Contractor shall submit for approval a complete list, in quadruplicate, of materials and equipment to be incorporated in the work.

7.1.2 The list shall include catalog numbers, cuts, diagrams, drawings and other descriptive data as may be required by the owner. No consideration will be given to partial lists submitted from time to time. Approval will be based on the manufacturer's published ratings. Any materials and equipment listed which are not in accordance with the specification requirements will be rejected.

## 7.2 CERTIFICATION

7.2.1 Certification shall be submitted with the shop drawings giving the name of the firm, the number of years of experience and a list of not less than ten of the firm's cathodic protection installations, five years old or more, which have been tested and found satisfactory.

7.2.2 The installation shall be supervised by a member of the National Association of Corrosion Engineers (NACE) accredited as a Corrosion Specialist. The name and qualifications of the supervisor shall be submitted with the shop drawings.

## 8.0 INSTALLATION

### 8.1 MAGNESIUM ANODES

8.1.1 All anodes shall be magnesium and shall be installed at the locations indicated on the Drawings.

8.1.2 All anodes shall be installed in native soil, a minimum of three feet from the structure to be protected and below the center line of that structure.

8.1.3 Anode lead wires shall be thermite brazed to the structure except for test station locations where the anode lead shall terminate on a test station lug with a lead wire thermite brazed to the structure.

8.1.4 Anodes shall be backfilled with native soil - sand or rock is not permissible.

## 8.2 WIRING

8.2.1 Underground wires, cables, and connections shall be buried at a minimum depth of 2'0" below grade, with a 6" minimum separation from other underground structures.

8.2.2 All splices and repairs to damaged cable associated with a cathodic protection system shall be sealed against moisture penetration.

8.2.3 All wiring shall be backfilled with material free from rocks and debris which could damage the insulation.

## 8.3 THERMITE BRAZING

8.3.1 Thermite brazing techniques shall comply with the manufacturer's recommendations. Only proper size cartridges and welders will be permitted.

8.3.2 Prior to brazing, an area of piping three inches square shall be cleaned to bright metal with a grinder or file.

8.3.3 The slag shall be removed from the completed braze with a hammer.

8.3.4 The adequacy of each braze shall be demonstrated by gently striking the top of the connection with a hammer.

8.3.5 The cleaned piping surface, including the brazed connection and any exposed copper wire, shall be coated with a cold applied coal tar compound. Recommended coating materials are Kopper's Bitumastic #50 or Royston Handicaps.

## 8.4 TEST STATIONS

8.4.1 Test stations shall be provided where indicated on the Drawings and shall be installed in accordance with the details given.

8.4.2 Test leads shall be #12 AWG solid copper conductors with TW insulation.

8.4.3 Thermite brazing techniques shall comply with this specification.

## 8.5 BONDS

8.5.1 Electrical continuity shall be provided along all underground metallic piping to be provided with cathodic protection by installing bond cables across every underground mechanical coupling.

8.5.2 Bonding techniques shall be in accordance with the details shown on the Drawing.

8.5.3 All bond cables shall be #4 AWG stranded copper cable with high molecular weight polyethylene insulation.

8.5.4 Thermite brazing techniques shall comply with this specification.

## 8.6 INSULATION

8.6.1 Flange insulation shall be provided to electrically isolate portions of the pipelines.

8.6.2 Where the pipe passes through concrete walls, the wall shall be sleeved and seals shall be placed between the pipe and the sleeve to provide both electrical isolation of the piping and a moisture seal.

8.6.3 Insulating materials shall be inspected and tested by the contractor to assure the integrity of the insulating joint.

8.6.4 No metallic structures shall be permitted in contact with the electrically isolated section of underground piping.

## 8.7 COATING INSPECTION

8.7.1 All coatings shall be visually inspected for "holidays" and "breaks" during construction. Electrical tests shall be conducted in the field with a portable high voltage, low amperage holiday detector. Electrical field testing shall conform to the procedure outlined hereafter. The contractor shall provide the electrical inspection equipment and shall furnish an operator for the equipment.

8.7.2 The electrical test equipment shall be portable low amperage adjustable voltage, pulse-type holiday detector. The holiday detector shall be furnished with a coil spring electrode for use with large coated pipe areas and a suitable brush type electrode for smaller coated bolt and structural surfaces.

## 11.0 TESTING

- 11.1 The corrosion engineering specialist and/or firm shall conduct tests of the cathodic protection system after completion of the installation. Testing will be performed in accordance with accepted practices as recommended by the National Association of Corrosion Engineers.
  - 11.1.1 All insulating fittings shall be tested to insure proper electrical isolation.
  - 11.1.2 Structure-to-soil potential measurements shall be made at representative locations throughout the system.
  - 11.1.3 Magnesium anode current outputs shall be recorded at all test stations in order to evaluate the system performance.
  - 11.1.4 The cathodic protection system shall be adjusted in such a manner as to comply with the criteria for protection as given in NACE RP-01-69.
- 11.2 The corrosion engineering specialist shall be responsible for cooperating with owners of foreign structures in order to coordinate corrosion control measures. Joint cathodic interferences tests shall be conducted with all interested parties to insure that the subject cathodic protection system is neither adversely affecting other underground metallic structures nor experiencing detrimental effects from neighboring cathodic protection systems.
- 11.3 In the event that interference problems are detected, the corrosion engineering specialist shall cooperate with the companies involved until a mutually satisfactory solution is reached.
- 11.4 A written report shall be submitted to the contractor and shall include all test data, and analysis of the data and instructions for operation and maintenance of the cathodic protection system.

## 12.0 GUARANTEE

- 12.1 All material and equipment shall be guaranteed for a period of one year from the date of the Final Report. Upon receipt of notice from the owner of failure of any part of the system during the guarantee period, new replacement parts shall be furnished and installed by the contractor at no additional cost. This guarantee is limited to defects in workmanship and materials.

BRADLEY ENGINEERING, P.C.  
CONSULTING ENGINEER

~~Hight Mt. Road~~  
Box 206, R. D. 6  
Troy, New York 12180

8 November, 1988

Norlite Corporation  
P. O. Box 694  
625 S. Saratoga Street  
Cohoes, New York 12047

Subject: Fuel Lines Pressure Tests


During the period of 10/13/88 thru 10/16/88 the LGF lines from the transfer pump station to the kiln pump house were pressure tested to ascertain that they were pressure tight.

The green line was pressurized to 60 psi at 1500 hrs. 10/13/88. A check of the line pressure at 0800 hrs. 10/14/88 indicated a residual pressure of 58 psi. The line proved to be pressure tight.

On 10/14/88 a test of the yellow and white lines was began. The yellow and white lines were pressurized to 60 and 58 psi respectively. The white line did not hold pressure. A check of the line brought to light the fact the packing of one inline valve was leaking. The valve was isolated and the line at 1600 hrs. was pressurized to 60 psi. A check of the pressure in the two lines was made at 0900 hrs. on 10/15/88. The white line maintained pressure at 59 psi. The yellow line had dropped to 56 psi. A check of the line gave an indication of a possible gasket leak on a segmented ball valve. It was decided to isolate the valve and retest. The system was isolated and pressurized to 60 psi. A check of the line was made at 0830 hrs. on 10/16/88. The pressure reading was holding at 59 psi.


It is our conclusion that the LGF pipelines from the transfer pumps to the kiln pump house are pressure tight and that they remain satisfactory for handling the Low Grade Fuels that they were designed to handle.

For Bradley Engineering, P.C.

  
William D. Bradley, P.E.

## VEGAPULS Radar Level Sensors

Ohmart/VEGA offers the widest variety of radar gauges on the market. The VEGAPULS 50 Series is a new generation of loop powered, low-cost level measurement sensors that are designed for use in simple measurement environments. The VEGAPULS 56 HT with its unique ceramic antenna makes radar level measurement possible in high temperature applications. The VEGAPULS 81, used in conjunction with advanced EchoFox™ software, is designed for use in heavily agitated process vessels. With this large selection of radar gauges, designed for a vast array of process applications, Ohmart/VEGA excels in providing customers with optimal solutions to their level and specialty measurement applications.



### Principle of Operation

#### Pulse

The sensor transmits energy in the form of microwave pulses. These pulses are directed toward a specific target that reflects the energy back to an antenna.

#### Target

The amount of energy that returns to the antenna depends on the reflective properties of the material being measured. Reflectivity can be determined by examining two characteristics, conductivity and dielectric constant (DK).

#### Return to the Antenna

The transit time of the microwave pulse that returns to the antenna is measured and used to calculate the distance to the target.

#### Reflectivity

Conductive products such as water, acids, etc., have very good reflectivity and can be measured regardless of the DK value. For non-conductive materials, the DK value alone determines the reflectivity. Materials with a low DK absorb a large portion of the microwaves transmitted by the radar sensor, thus reducing the energy returned to the antenna.

*Microwave pulse signal transmitted to product surface.*

*Reflected pulse signal returned from product surface to sensor antenna.*

# VEGASON


## Ultrasonic continuous level measurement

### One of 12 Ohmart/VEGA advanced technologies

The VEGASON ultrasonic transducers and electronics represent one of twelve technologies available from Ohmart/VEGA for level detection and continuous measurement. Given the parameters of a level problem it is often the best technology that can be applied relative to both performance and economics. Other Ohmart/VEGA technologies include miniature and point level ultrasonics, nuclear, capacitance, pulse radar, microwave barrier, vibration, hydrostatic, electromechanical, conductive, and total interface profile. The quality of our range of VEGASON ultrasonic level transmitter models is attested by thousands of successful applications worldwide, especially in the measurement of difficult solids, granules, and powders.

### Ultrasonic measuring principles

VEGASON ultrasonic transducers are located at the top of the tank or silo. Piezoelectric high-performance crystals are used within the transducer. Short ultrasonic pulses are emitted to the product surface. The pulses reflected by the product are received by the transducer operating as transmitter and receiver. The time taken to receive the reflected pulse is measured by the electronics, and is linear with and proportional to the distance between the face of the transducer and the product, provided that the density of the airspace remains constant. The reflection time is then converted into a level value for display/output purposes. Due to the use of high-energy pulses non-contact measurement of liquids and solids is possible with this continuous measuring principle.



### 19 models *new short and long range options*

Ohmart/VEGA offers nineteen ultrasonic VEGASON models covering ranges from 12 inches to 196 feet. In addition, Ohmart offers a wide range of miniature and standard ultrasonic gap switches, transducers, and transmitters, which completes the product offering for measuring levels of liquids and solids from a few millimeters in vials to 196 feet for large storage tanks (see Ohmart ultrasonic catalog). This broad range of products provide users with an ideal model for each application. This broad range of products provide performance and significant cost benefits for many applications where more powerful transducer systems would not



# CERTIFICATION

**Continental Disc®  
Corporation**

3160 W. Heartland Drive • Liberty, MO 64068-3385 USA • (816) 792-1500 • Fax (816) 792-2277 / 5447

Manufactured and Tested under an ISO-9001 Certified  
Quality System. TUV-CERT Certificate Reg. No. 12 100 9200.  
Inspection Certificate EN 10 204 3.1.8: 1991

Date: 9/ 6/01

Sold To: NORLITE CORP.

S.O. No: 01-09-090-00

Customer Order No: 981307

Item: 01

Mfg No: 340727

Quantity: 5

Type: 6" CAL-VAC (FS) Continental Rupture Disc

*FOR TANKS  
100A, 100B, 100C  
200B, 200C*

Material: 316 SS Top Section  
Teflon Seal  
Teflon Girdle

Requested Rupture Pressure and Temperature:

POS RATED: 20 psig MAX @ 80 deg F

VAC PRESSURE RATING: 8 MIN to 14 MAX in. water @ 80 deg F

\* POS Burst Test Results:

1) 17.9      2) 17.0

VAC Burst Test Results:

1) 10.0      2) 11.0

Stamped Rupture Pressure and Temperature:

17.5 psig @ 80 deg F

VAC PRESSURE RATING: 8 MIN to 14 MAX in. water @ 80 deg F

Ambient Rupture Pressure and Temperature:

17.7 psig @ 72 deg F

CONTINENTAL DISC CORPORATION

\* Certification Chart Number: 511FY  
(Analysis Available Upon Request)

*ALLEN* 2012 Section 509 Process  
DIRECTOR OF QUALITY ASSURANCE





# CERTIFICATION

**Continental Disc<sup>®</sup>  
Corporation**

3160 W. Heartland Drive • Liberty, MO 64068-3385 USA • (816) 792-1500 • Fax (816) 792-2277 / 5447

Manufactured and Tested under an ISO-9001 Certified  
Quality System, TUV-CERT Certificate Reg. No. 12 100 9200.  
Inspection Certificate EN 10 204 3.1.B: 1991

Date: 9/13/01

Sold To: NORLITE CORP.

S.O. No: 01-08-890-00

Customer Order No: 981231

Item: 01

Mfg No: 340922

Quantity: 2

Type: 3" CAL-VAC (FS) Continental Rupture Disc

*FOR TANKS*

Material: 316 SS Top Section  
Teflon Seal  
Teflon Girdle

*101A, 101B*

*102A, 102B*

Requested Rupture Pressure and Temperature:

POS RATED: 20 psig MAX @ 80 deg F

VAC PRESSURE RATING: 8 MIN to 14 MAX in. water @ 80 deg F

POS Burst Test Results:

1) 17.0      2) 18.4

VAC Burst Test Results:

1) 11.5      2) 11.5

Stamped Rupture Pressure and Temperature:

17.7 psig @ 80 deg F

VAC PRESSURE RATING: 8 MIN to 14 MAX in. water @ 80 deg F

Ambient Rupture Pressure and Temperature:

17.9 psig @ 72 deg F

CONTINENTAL DISC CORPORATION

*Dean Andersen*

DIRECTOR OF QUALITY ASSURANCE



# CERTIFICATION

**Continental Disc<sup>®</sup>  
Corporation**

3160 W. Heartland Drive • Liberty, MO 64068-3385 USA • (816) 792-1500 • Fax (816) 792-2277 / 5447

Manufactured and Tested under an ISO-9001 Certified  
Quality System. TUV-CERT Certificate Reg. No. 12 100 9200.  
Inspection Certificate EN 10 204 3.1.B: 1991

Date: 1/17/02

Sold To: NORLITE CORP.

S.O. No: 02-01-296-00

Customer Order No: 982374

Item: 03

Mfg No: 344757

Quantity: 2

*FOR TANK*

*200A*

Type: 6" CDCV (FS) Continental Rupture Disc

Material: 316 SS Top Section  
Teflon Seal  
316 SS Vacuum Support

Requested Rupture Pressure and Temperature:  
RATED: 20 psig MAX @ 80 deg F

\* Burst Test Results:  
1) 17.1      2) 19.1

Stamped Rupture Pressure and Temperature:  
18.1 psig @ 80 deg F

Ambient Rupture Pressure and Temperature:  
18.3 psig @ 72 deg F

CONTINENTAL DISC CORPORATION

DIRECTOR OF QUALITY ASSURANCE

Certified Chart Number: 503AR  
(Chemical Analysis Available Upon Request)

# Stetson-Dale

1225 Peoples Avenue, Troy, NY 12180 / (518) 274-8663

## PIPING SPECIFICATIONS


SPEC. LGF		PIPING MATERIAL Carbon Steel		
ISSUE 1		REV. 0		SERVICE LIMITS 150 psig @ 300°F
ITEM	DIAMETER	CONN	CLASS	MATERIAL SPECIFICATION
PIPE	½ - 1½" 2 - 6"	S.E. Plain	Sch 80 Sch 40	Seamless carbon steel per ASTM A106 or A53 Gr. B
FITTING	½ - 1½" 2 - 6"	S.E. B.W.	2000# Sch 40	Forged carbon steel ASTM A105 Seamless carbon steel ASTM A234 or A106
FLANGES	½ - 1½"	Slip-on	150#	Forged carbon steel ASTM A105
UNION	None			
BOLTING	Bolt Studs - cadmium plated carbon steel A307 Gr. 2 Nuts - cadmium plated carbon steel A563 Gr. A			
GASKETS	Compressed asbestos Garlock Style 8748			
SEALANT	Teflon tape for threaded connections			




*K. M. ...*



CHEMICAL	IRON BASE ALLOYS										COPPER BASE ALLOYS				NICKEL BASE ALLOYS		
	TYPE	CUT BODY	H 100%	H 50%	H 25%	1/2 C	1/4 C	1/8 C	1/16 C	1/32 C	1/64 C	1/128 C	1/256 C	1/512 C	1/1024 C	1/2048 C	1/4096 C
ACETYLACETONE																	
ACETYL CHLORIDE																	
ACETYL SALICYLIC ACID																	
ACETYL THIOPHENE																	
ACETYLENE																	
ACETYLENE TETRACHLORIDE																	
ACONITIC ACID																	
ACRIDINE																	
ACROLEIN																	
ACRYLIC ACID																	
ACRYLONITRILE																	
ADIPIC ACID																	
ADIPIC ACID (17% INIERIC ACID (38%))																	
ALCOHOL, ETHYL																	
ALCOHOL, METHYL																	
ALDRIN																	
ALIPHATIC ALCOHOL SULFONATES																	







**CORROSION RATE**

- LESS THAN 0.002" PER YEAR
- LESS THAN 0.020" PER YEAR
- FROM 0.020" TO 0.050" PER YEAR
- ✕ GREATER THAN 0.050" PER YEAR

**ION-METALLIC RATINGS**

- FULLY SATISFACTORY
- SUFFICIENT RESISTANCE
- ✕ DUBIOUS UTILITY
- SEVERELY ATTACKED

800									
700									
600									
500									
400									
300									
212									
175									
125									
75									

CONCENTRATION, %

70 40 60 80 100



## 40 CFR 264/ 6 NYCRR 373-2.28 Subpart BB & MACT 40 CFR 61 Subpart V Compliance Requirements

Equipment/ Locations	Monitoring Procedure	Procedure When Potential Leak/ Leak Detected	Repair Procedures	Record In Inspection Log
<p>40 CFR 264.1050 6 NYCRR 373-2.28(a) 40 CFR 61.242-1</p> <p>Applicability</p>	<p>Each piece of equipment shall be marked in such a manner that it can be distinguished readily from other pieces of equipment.</p> <p>Equipment that is in vacuum service is excluded from these requirements</p>	<p>The unique ID# for the leaking equipment is used to identify and label the equipment in questions with a weatherproof tag to signify repair is needed</p>	<p>Repair as soon as practicable.</p> <p>First Attempt: Within 5 days of leak detected.</p> <p>Completed: Within 15 days of leak detected.</p> <p>Remove repair identification.</p>	<p>Norlite has established a set of drawings which indicates a unique ID # for each connector, flange, valve, pump, agitator, etc., which are regulated under the indicated regulations. Norlite will not maintain an individual tag system in the field for this equipment</p> <p>Norlite uses either green and yellow paint or a red plastic tag marked "Subpart BB/V" to readily distinguish regulated equipment from non-regulated equipment</p>
<p>40 CFR 264.1052 6 NYCRR 373-2.28(c) 40 CFR 61.242-2</p> <p>Pumps in Light Liquid Service</p> <p>Double Mechanical Pumps: 100A, 100B, 200A, 200B, 3 Off-Loading Bay Pumps</p> <p>Single Seal Pump: 100C, 200C</p>	<p><u>Weekly</u>: Visually inspect for liquid Dripping from pump seal, results can be found on weekly RCRA Inspection forms</p> <p><u>Monthly</u>: Monitor for leaks using Method 21, result can be found in the weekly Fuel Farm VOC Readings report under Subpart CC</p> <p><u>Monthly</u>: check of audible alarm for double mechanical seal system, results can be found attached to the weekly Fuel Farm VOC Readings report under Subpart CC</p>	<p>Leak detected at <math>\geq 10,000</math> ppm</p> <p>Leak detected if liquids dripping from pump seal</p> <p>The leak detection sensor system for the double mechanical system sounds an audible alarm, a leak has been detected</p> <p>Visibly mark the pump as out of service with a weatherproof repair identification (i.e. tag, color tape), with the date leak found.</p>	<p>Repair as soon as practicable.</p> <p>First Attempt: Within 5 days of leak detected.</p> <p>Completed: Within 15 days of leak detected.</p> <p>Remove repair identification.</p>	<p>IF Leak Occurs, following information will be recorded on a <b>Leak Detection Sheet</b></p> <p>Monitor I.D. No. Operator identification. Equipment tag No. Date of evidence potential leak. Date leak was detected. Date each repair attempt was made and Method used. VOC reading after repair "Repair Delayed" and reason. Documentation to support delay of repair Signature of operator if unit must be shut down. Date expected of successful repair. Date of successful repair.</p> <p>Out of service pumps will also be documented on the Fuel Farm Pre-Shift records as well as the weekly RCRA Inspection report if witnessed during the time of the inspection</p>
<p>40 CFR 264.1053 6 NYCRR 373-2.28(d) 40 CFR 61.242-3</p> <p>Compressors</p>	<p>Norlite does not have any compressors which are regulated by the listed regulations</p> <p>Monthly: check of audible alarm for barrier fluid system</p>	<p>The leak detection sensor system for the double mechanical system sounds an audible alarm, a leak has been detected</p> <p>Visibly mark the compressor as out of service with a weatherproof repair identification (i.e. tag, color tape), with the date leak found.</p>	<p>Repair as soon as practicable.</p> <p>First Attempt: Within 5 days of leak detected.</p> <p>Completed: Within 15 days of leak detected.</p> <p>Remove repair identification.</p>	<p>Same as Pumps should a compressor be installed which meets the requirements of the stated regulations</p>
<p>Monitoring shall comply with Method 21, 40 CFR Part 60 – Norlite uses a Photovac 2020 Pro Plus and complies with 40 CFR 264.1034. Note that Norlite uses a detection of 500 ppm or higher to trigger a repair event. Evidence of leak - visual, audible, olfactory, or any other detection method. If delay in repair is required, delay will be managed in accordance with 40 CFR 263.1059. First attempt at repair include, but not limited to: (1) Tightening of bonnet bolts (2) Replacement of bonnet bolts (3) Tightening of packing gland nuts (4) Injection of lubricant into lubricated packing.</p>				

## 40 CFR 264/ 6 NYCRR 373-2.28 Subpart BB & MACT 40 CFR 61 Subpart V Compliance Requirements

Equipment/Location	Monitoring Procedure	Procedure When Leak/Defect Detected	Repair Procedure	Record In Inspection Log
<p>40 CFR 264.1054 6 NYCRR 373-2.28(e) 40 CFR 61.242-4</p> <p>Pressure Relief Devices in Gas/Vapor Service</p>	<p>Norlite maintains all storage tanks with a vent system which maintains a consistent pressure within the tank.</p> <p>The tank vent system is a closed vent system and therefore exempt from the condition of the stated regulations</p>	<p>The tank vent system is a closed vent system and therefore exempt from the condition of the stated regulations</p>	<p>The tank vent system is a closed vent system and therefore exempt from the condition of the stated regulations</p>	<p>The tank vent system is a closed vent system and therefore exempt from the condition of the stated regulations</p>
<p>40 CFR 264.1055 6 NYCRR 373-2.28(f) 40 CFR 61.242-5</p> <p>Sampling Connection Systems</p>	<p><i>In-situ</i> sampling systems and sampling systems without purges are exempt from the requirements of the listed regulations</p>	<p><i>In-situ</i> sampling systems and sampling systems without purges are exempt from the requirements of the listed regulations</p>	<p><i>In-situ</i> sampling systems and sampling systems without purges are exempt from the requirements of the listed regulations</p>	<p><i>In-situ</i> sampling systems and sampling systems without purges are exempt from the requirements of the listed regulations</p>
<p>40 CFR 264.1056 6 NYCRR 373-2.28(g) 40 CFR 61.242-6</p> <p>Open-ended valves or lines</p>	<p><u>Daily visual</u>: Inspect each valve/line to be equipped with a cap/plug and sealed</p>	<p>Immediate notification to the Fuel Farm Manager for replacement</p>	<p>Missing caps and plugs are to be replaced upon discovery of their absence</p>	<p>Evidence of missing caps and plugs will be recorded in either the Fuel Farm Pre-shift inspection logs in the comments section or on the weekly RCRA inspection reports if witnessed during the time of the inspection</p>
<p>40 CFR 264.1057 6 NYCRR 373-2.28(h) 40 CFR 61.242-7</p> <p>Valves in gas/vapor service or in light liquid service</p>	<p><u>Monthly</u>: Monitor for leaks which are greater than 10,000 ppm.</p> <p><u>Quarterly</u>: If have two consecutive months with no detected leaks, can start monitoring first month of each quarter</p> <p>If a leak is found, must start monthly monitoring again until there are two consecutive months with a detection</p> <p><u>Annual</u>: Any valves designated as "unsafe-to-monitor" are required to be monitored at least annually</p> <p>Results for the quarterly and annual testing can be found in the Quarterly Subpart BB reports</p>	<p>Leak detected at <math>\geq 10,000</math> ppm</p> <p>Visibly mark the valve as out of service with a weatherproof repair identification (i.e. tag, color tape), with the date leak found</p>	<p>Repair as soon as practicable.</p> <p>First Attempt: Within 5 days of leak detected.</p> <p>Completed: Within 15 days of leak detected.</p> <p>Remove repair identification.</p>	<p>IF Leak Occurs, following information will be recorded on a <b>Leak Detection Sheet</b></p> <p>Monitor I.D. No. Operator identification. Equipment tag No. Date of evidence potential leak. Date leak was detected. Date each repair attempt was made and Method used. VOC reading after repair "Repair Delayed" and reason. Documentation to support delay of repair Signature of operator if unit must be shut down. Date expected of successful repair. Date of successful repair</p> <p>Any valve found with a reading above background, will be documented in the quarterly Subpart BB Inspection reports</p>

Monitoring shall comply with Method 21, 40 CFR Part 60 – Norlite uses a Photovac 2020 Pro Plus and complies with 40 CFR 264.1034. Note that Norlite uses a detection of 500 ppm or higher to trigger a repair event. Evidence of leak - visual, audible, olfactory, or any other detection method. If delay in repair is required, delay will be managed in accordance with 40 CFR 263.1059. First attempt at repair include, but not limited to: (1) Tightening of bonnet bolts (2) Replacement of bonnet bolts (3) Tightening of packing gland nuts (4) Injection of lubricant into lubricated packing.

### 40 CFR 264/ 6 NYCRR 373-2.28 Subpart BB & MACT 40 CFR 61 Subpart V Compliance Requirements

Equipment/Location	Monitoring Procedure	Procedure When Leak/Defect Detected	Repair Procedure	Record In Inspection Log
<p>40 CFR 264.1058 6 NYCRR 373-2.28(i) 40 CFR 61.242-8</p> <p>Pressure relief devices in light liquid service, and flanges and other connectors</p> <p>Tank Rupture Disk System</p>	<p>Monitored within 5 days if evidence of a potential leak is found by visual, audible, olfactory, or any other detection method.</p> <p>Evidence of a potential leak will be recorded on the Fuel Farm pre-shift Inspection form in the comments section or on the Weekly RCRA Inspection report if witnessed during the time of the inspection</p>	<p>If an instrument reading of 10,000 ppm or greater is measured, a leak is detected</p> <p>As per 40 CFR 61.242-8 If evidence of a potential leak is found by visual, audible, olfactory, or any other detection method at pressure relief devices in liquid service and connectors, the owner or operator shall follow either one of the following procedure:</p> <p>(1) The owner or operator shall monitor the equipment within 5 days</p> <p>(2) The owner or operator shall eliminate the visual, audible, olfactory, or other indication of a potential leak.</p>	<p>Repair as soon as practicable.</p> <p>First Attempt: Within 5 days of leak detected.</p> <p>Completed: Within 15 days of leak detected.</p> <p>Remove repair identification.</p>	<p>If Leak Occurs, following information will be recorded on a <b>Leak Detection Sheet</b>:</p> <p>Monitor I.D. No. Operator identification. Equipment tag No. Date of evidence potential leak. Date leak was detected. Date each repair attempt was made and Method used. VOC reading after repair "Repair Delayed" and reason. Documentation to support delay of repair Signature of operator if unit must be shut down. Date expected of successful repair. Date of successful repair</p> <p>If a rupture disk is found to be leaking during a quarterly Subpart BB Inspection, it will be detailed in that quarterly report</p>
<p>40 CFR 264.1059 6 NYCRR 373-2.28(j) 40 CFR 61.242-10</p> <p>Delay of Repairs</p>	<p>Delay of repair of equipment for which leaks have been detected will be allowed if repair within 15 days is technically infeasible without a process unit shutdown.</p> <p>Delay of repair will be allowed for equipment that is isolated from the process and that does not remain in contact with hazardous waste or remain in VHAP service.</p> <p>As per 40 CFR 61.242-10 Delay of repair for pumps will be allowed if: (1) Repair requires the use of a dual mechanical seal system that includes a barrier fluid system. (2) Repair is completed as soon as practicable, but not later than 6 months after the leak was detected.</p>			<p>If a delay of repairs occurs, the reason will be detailed on the <b>Leak Detection Sheet</b> used for the detected leak.</p> <p>Delay of repairs for equipment found leaking during a quarterly Subpart BB Inspection will be detailed in the Inspection report as well as well as on the Weekly RCRA Inspection report</p>
<p>Monitoring shall comply with Method 21, 40 CFR Part 60 – Norlite uses a Photovac 2020 Pro Plus and complies with 40 CFR 264.1034. Note that Norlite uses a detection of 500 ppm or higher to trigger a repair event. Evidence of leak - visual, audible, olfactory, or any other detection method. If delay in repair is required, delay will be managed in accordance with 40 CFR 263.1059. First attempt at repair include, but not limited to: (1) Tightening of bonnet bolts (2) Replacement of bonnet bolts (3) Tightening of packing gland nuts (4) Injection of lubricant into lubricated packing.</p>				

### 40 CFR 264/ 6 NYCRR 373-2.28 Subpart BB & MACT 40 CFR 61 Subpart V Compliance Requirements

Equipment/Location	Monitoring Procedure	Procedure When Leak/Defect Detected	Repair Procedure	Record In Inspection Log
<p>40 CFR 264.1060 6 NYCRR 373-2.28(k) 40 CFR 61. 242-11</p> <p>Closed Vent Systems and Controls</p>	<p>Norlite utilizes two rotary kilns as control devices for the destruction of any VHAP from the Closed Vent System</p> <p>Enclosed combustion devices shall be designed and operated to reduce the VHAP emissions vented to them with an efficiency of 95 percent or greater</p> <p>If the closed vent system is constructed of hard-piping, the owner or operator shall comply with the following requirements:</p> <p><u>Annual</u>: Conduct visual inspections for visible, audible, or olfactory indications of leaks</p> <p>Results of the visual inspection can be found in the 3<sup>rd</sup> quarter Subpart BB reports.</p>	<p>Leak detected at <math>\geq 500</math> ppm or by visual inspections</p> <p>If a vapor collection system or closed vent system is operated under a vacuum, it is exempt from the inspection requirements</p>	<p>Repair as soon as practicable.</p> <p>First Attempt: Within 5 days of leak detected.</p> <p>Completed: Within 15 days of leak detected.</p> <p>Remove repair identification.</p>	<p>Norlite maintains the kilns as per the regulations of 40 CFR 63 Subpart EEE which is a minimum DRE of 99.99%. A final report of any testing is submitted to the USEPA and NYSDEC</p> <p>If Leak Occurs, following information will be recorded on a <b>Leak Detection Sheet</b></p> <p>Monitor I.D. No. Operator identification. Equipment tag No. Date of evidence potential leak. Date leak was detected. Date each repair attempt was made and Method used. VOC reading after repair "Repair Delayed" and reason. Documentation to support delay of repair Signature of operator if unit must be shut down. Date expected of successful repair. Date of successful repair</p>
<p>40 CFR 264.1061 6 NYCRR 373-2.28(l) 40 CFR 61.243-1</p> <p>Alternative standards for valves in gas/vapor service or in light liquid service: percentage of valves allowed to leak</p>	<p>Can elect to have all valves within a process unit comply with an allowable percentage of valves leaking of equal to or less than 2.0 percent</p> <p>Must meet following requirements:</p> <p>Must notify the Administrator that the owner or operator has elected to have all valves within a process unit comply with the allowable percentage of valves leaking before implementing this alternative standard</p> <p>A performance test shall be conducted initially upon designation, annually, and at other times requested by the Administrator</p>	<p>Performance tests shall be conducted in the following manner:</p> <p>(1) All valves in VHAP service within the process unit shall be monitored within 1 week</p> <p>(2) If an instrument reading of 10,000 ppm or greater is measured, a leak is detected</p> <p>(3) The leak percentage is determined by dividing the number of leaking valves by the number of total valves in VHAP service</p>	<p>Repair as soon as practicable.</p> <p>First Attempt: Within 5 days of leak detected.</p> <p>Completed: Within 15 days of leak detected.</p>	<p>Details of the performance test as well as the annual test will be recorded in the Quarterly/Annual Subpart BB Inspection report. Any leaks will also be documented on a <b>Leak Detection Sheet</b></p> <p>Norlite may consider applying the alternative standards in the future due to the low number of leaks which are found</p>
<p>Monitoring shall comply with Method 21, 40 CFR Part 60 – Norlite uses a Photovac 2020 Pro Plus and complies with 40 CFR 264.1034. Note that Norlite uses a detection of 500 ppm or higher to trigger a repair event. Evidence of leak - visual, audible, olfactory, or any other detection method. If delay in repair is required, delay will be managed in accordance with 40 CFR 263.1059. First attempt at repair include, but not limited to: (1) Tightening of bonnet bolts (2) Replacement of bonnet bolts (3) Tightening of packing gland nuts (4) Injection of lubricant into lubricated packing.</p>				

### 40 CFR 264/ 6 NYCRR 373-2.28 Subpart BB & MACT 40 CFR 61 Subpart V Compliance Requirements

Equipment/Location	Monitoring Procedure	Procedure When Leak/Defect Detected	Repair Procedure	Record In Inspection Log
40 CFR 264.1062 6 NYCRR 373-2.28(m) 40 CFR 61.243-2  Alternative standards for valves in VHAP service—skip period leak detection and repair	<p>After 2 consecutive quarterly leak detection periods with the percentage of valves leaking equal to or less than 2.0, an owner or operator may begin to skip one of the quarterly leak detection periods for the valves in VHAP service</p> <p>After five consecutive quarterly leak detection periods with the percentage of valves leaking equal to or less than 2.0, an owner or operator may begin to skip three of the quarterly leak detection periods for the valves in VHAP service</p> <p>If the percentage of valves leaking is greater than 2.0, the owner or operator shall comply with the requirements as described in 40 CFR 264.1057, 6 NYCRR 373-2.28(h), 40 CFR 61.242-7, but may again elect to use this section</p>	<p>Leak detected at <math>\geq 10,000</math> ppm</p> <p>Visibly mark the pump as out of service with a weatherproof repair identification (i.e. tag, color tape), with the date leak found</p>	<p>Repair as soon as practicable.</p> <p>First Attempt: Within 5 days of leak detected.</p> <p>Completed: Within 15 days of leak detected</p>	<p>IF Leak Occurs, following information will be recorded on a <b>Leak Detection Sheet</b>:</p> <p>Monitor I.D. No.                      Operator identification.                      Equipment tag No.                      Date of evidence potential leak.                      Date leak was detected.                      Date each repair attempt was made and Method used.                      VOC reading after repair                      "Repair Delayed" and reason.                      Documentation to support delay of repair                      Signature of operator if unit must be shut down.                      Date expected of successful repair.                      Date of successful repair</p>
Monitoring shall comply with Method 21, 40 CFR Part 60 – Norlite uses a Photovac 2020 Pro Plus and complies with 40 CFR 264.1034. Note that Norlite uses a detection of 500 ppm or higher to trigger a repair event. Evidence of leak - visual, audible, olfactory, or any other detection method. If delay in repair is required, delay will be managed in accordance with 40 CFR 263.1059. First attempt at repair include, but not limited to: (1) Tightening of bonnet bolts (2) Replacement of bonnet bolts (3) Tightening of packing gland nuts (4) Injection of lubricant into lubricated packing.				

### 40 CFR 264/ 6 NYCRR 373-2.28 Subpart BB & MACT 40 CFR 61 Subpart V Compliance Requirements

Equipment/Location	Reporting as per 40 CFR 264.1065 & 6 NYCRR 373-2.28(p)	Reporting as per 40 CFR 61.247	Record In Inspection Log
<p>40 CFR 264.1065 6 NYCRR 373-2.28(p) 40 CFR 61.247</p> <p>Reporting Requirements</p>	<p>A semiannual report shall be submitted to the Regional Administrator by dates specified by the Regional Administrator.</p> <p>The report shall include the following information:</p> <p>The EPA ID#, name, and address</p> <p>For each month during the semiannual reporting period:</p> <p>(i) The ID # of each leaking valve (ii) The ID # of each leaking pump (iii) The ID# of each compressor</p> <p>Dates of unit shutdowns that occurred within the semiannual reporting period.</p> <p>For each month during the semiannual reporting period, dates when the control device exceeded or operated outside of the design specifications and was not corrected within 24 hours, the duration and cause of each exceedance, and any corrective measures taken.</p> <p>If, during the semiannual reporting period, leaks from valves, pumps, and compressors are repaired as required, and the control device does not exceed or operate outside of the design specifications for more than 24 hours, a report to the Regional Administrator is not required</p>	<p>A report shall be submitted to the Administrator semiannually starting 6 months after the initial report that includes the following information:</p> <p>Process unit identification</p> <p>For each month during the semiannual reporting period:</p> <p>(i) Number of valves for which leaks were detected (ii) Number of valves for which leaks were not repaired (iii) Number of pumps for which leaks were detected (iv) Number of pumps for which leaks were not repaired (v) Number of compressors for which leaks were detected (vi) Number of compressors for which leaks were not repaired (vii) The facts that explain any delay of repairs and, where appropriate, why a process unit shutdown was technically infeasible.</p> <p>Dates of process unit shutdowns which occurred within the semiannual reporting period</p> <p>Revisions to items reported if changes have occurred since the initial report or subsequent revisions to the initial report</p> <p>The results of all performance tests and monitoring to determine compliance with no detectable emissions conducted within the semiannual reporting period</p> <p>In the first report submitted, the report shall include a reporting schedule stating the months that semiannual reports shall be submitted. Subsequent reports shall be submitted according to that schedule, unless a revised schedule has been submitted in a previous semiannual report.</p>	<p>As per 40 CFR 264.1065(4)(b) &amp; 6 NYCRR 373-2.28(p)(2), there is no requirement for a semi-annual report due to any leaking equipment being repaired as required and the control device not operating outside of design specifications.</p> <p>Should a semi-annual report ever be required, the report would be a standalone document and filed as such.</p> <p>As per 40 CFR 61.247, Norlite does not submit a semi-annual report to the Administrator. Due to the extremely low number of leaks which exist, Norlite uses the quarterly Subpart BB reports to document the information required in the referenced regulation.</p>

# Norlite Corporation Subpart CC Inspection Program

---

## **Background**

Norlite Corporation (Norlite) operates six vertical above ground tanks, four horizontal covered aboveground tanks, and five other ancillary tanks for a total storage capacity of 155,579 gallons as per 6 NYCRR 373-2.29. These tanks are subject to routine and scheduled inspections as per 6 NYCRR 373-2.29(e)(7)(iii)(a): the fixed roof and its closure devices shall be visually inspected by the owner or operator to check for defects that could result in air pollutant emissions. The closure devices shall be designed to operate such that when the closure device is secured in the closed position there are no visible cracks, holes, gaps, or other open spaces in the closure device or between the perimeter of the cover opening and the closure device. For the purpose of this inspection, closure devices on the tanks are flanged and the inspection will focus on the flange connection. Overall defects to inspect for include, but are not limited to, visible cracks, holes, or gaps in the roof sections or between the roof and the tank wall; broken, cracked, or otherwise damaged gaskets; and broken or missing hatches, access covers, caps, or other closure devices. As per 6 NYCRR 373-2.29(i)(2): the owner or operator shall develop and implement a written plan and schedule to perform the inspections and monitoring required. The owner or operator shall incorporate this plan and schedule into the facility inspection plan required under subdivision 373-2.2(g) of this Subpart.

This document serves as a written plan and schedule to perform the required inspections and monitoring detailed in 6 NYCRR 373-2.29(e)(7)(iii)(a). As detailed in 6 NYCRR 373-2.29(e)(7)(iii)(c)(3): the owner or operator shall perform an initial inspection of the air emission control equipment and thereafter, the owner or operator shall perform the inspections at least once every year. Norlite will conduct an annual visual inspection for defects, cracks, holes, gaps, damaged gaskets or other defects which could result in air pollution emissions in conjunction with one of the quarterly Subpart BB inspections conducted by Norlite personnel. The results of the visual inspections will be kept on-site for three years and then stored off-site for the life of the facility.

## **Equipment to be Inspected**

Norlite personnel will inspect the tanks listed in Module IV of the Part 373 Permit issued to Norlite on January 18, 2008. In short these tanks are Tanks 100A, 100B, 100C, 200A, 200B, 200C, 300, 400, 500, 600, 101A, 101B, 102A, 102B, and SP100. Specific drawings for these tanks and their associated equipment can be found in Attachment M of the Part 373 permit issued to Norlite on January 18, 2008. The specific drawing numbers are as follows: NY003-5010, NY003-1312, NY003-1314, NY003-1315, and NY003-1317. While 6 NYCRR 373-2.29(e)(7)(iii)(a) specifies a visual inspection of only the fixed roof and its closure devices, where accessible Norlite will visually inspect the entire outer tank surface plus any closure devices on the tank

# Norlite Corporation Subpart CC Inspection Program

---

surface. Any other ancillary equipment attached to the tank is covered under 6 NYCRR 373-2.28 and will not be included in this inspection.

## **Inspection Results**

As per 6 NYCRR 373-2.29(j)(2), the owner or operator shall record: a. a tank identification number as selected by the owner or operator, b. the date of the inspection was conducted, and c. any defects found. For each defect found during the inspection, the following information will be recorded: the location of the defect, a description of the defect, the date of detection, and corrective action taken to repair the defect. If the repair of the defect is delayed in accordance with the provisions of subdivision 373-2.29(e)(11), the owner or operator shall also record the reason for the delay and the date that completion of repair of the defect is expected.

## **Requirements for Defect Repairs**

As per 6 NYCRR 373-2.29(e)(11): the owner or operator shall repair each defect detected during an inspection as follows:

(i) The owner or operator shall make first efforts at repair of the defect no later than 5 calendar days after detection, and repair shall be completed as soon as possible but no later than 45 calendar days after detection.

(ii) Repair of a defect may be delayed beyond 45 calendar days if the owner or operator determines that repair of the defect requires emptying or temporary removal from service of the tank and no alternative tank capacity is available at the site to accept the hazardous waste normally managed in the tank. In this case, the owner or operator shall repair the defect the next time the process or unit that is generating the hazardous waste managed in the tank stops operation. Repair of the defect shall be completed before the process or unit resumes operation.

## **Requirements of 40 CFR 265.1084(d)**

As per 40 CFR 265.1084(d)(1): the test shall be conducted in accordance with the procedures specified in Method 21 of 40 CFR part 60, appendix A. Each potential leak interface on the cover and associated closure devices shall be checked. Norlite currently conducts Method 21 testing on the agitators of all the tanks listed previously in this document. As per 40 CFR 265.1084(d)(9): for the seals around a rotating shaft that passes through a cover opening, the arithmetic difference between the maximum organic concentration indicated by the instrument and the background level shall be compared with the value of 10,000 ppm. If the difference is less than 10,000 ppm, then the potential leak interface is determined to operate with no

# Norlite Corporation Subpart CC Inspection Program

---

detectable organic emissions. Norlite uses a limit of 500 ppm as a determination of leak. Any readings over 500 ppm will trigger maintenance to be conducted on the agitator packing.

## **Inspection Form**

See the attached form for an example of the form which will be used to conduct and document the annual inspection.

# Norlite Subpart CC Annual Inspection

Visual Inspection

PURSUANT TO 6NYCRR 373-2.29

INSPECTION DATE: \_\_\_\_\_

INSPECTOR NAME: Thomas Van Vranken

**NORLITE CORPORATION**  
628 South Saratoga Street  
Cohoes, NY 12047

TANK ID#	Drawing Reference	Defects Found (Yes or No)	Description of Defect Including Location, Date, and Corrective Action Taken, and Reason for Delay if One Exists
100A	Subpart CC/DD #1		
100B	Subpart CC/DD #1		
100C	Subpart CC/DD #1		
200A	Subpart CC/DD #1		
200B	Subpart CC/DD #1		
200C	Subpart CC/DD #1		
300	Subpart CC/DD #3		
400	Subpart CC/DD #3		
500	Subpart CC/DD #3		
600	Subpart CC/DD #3		
101A	Subpart CC/DD #2		
101B	Subpart CC/DD #2		
102A	Subpart CC/DD #2		
102B	Subpart CC/DD #2		
SP100	Subpart CC/DD #4		

INSPECTOR SIGNATURE: \_\_\_\_\_